

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6/DFS/MS/EH/2024/SZ/212

Dated..01/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the Name & Style of **M/s Pind Balluchi - Grills & Platters** running at **ground floor** of the building comprised of Basement, Stilt, Ground + Three Upper Floors located at A-3, Pamposh Enclave, Greater Kailash-1 (TE Hotel), New Delhi 110048 owner/occupied by A Unit of Classic Hospitality was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/SZ/2021/184 dated 16/04/2021. The restaurant premise was re-inspected by the officer concerned of this department on 25/06/2024 in the presence of Mr. Praveen Kumar (Manager) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/07/2024 at New Delhi by

  
**(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE**

Copy to: -

1. The Addl. Commissioner of Police (Lic/Branch) 1<sup>st</sup> Floor PS Defence Colony New Delhi 110049 (Ref. MHA Portal ID 2023092716506 dated 31/05/2024)

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

77  
77  
आजादी का  
अमृत महोत्सव

## INSPECTION REPORT

1	Name & Address of the Building	M/s Pind Balluchi- Grills & Platters, A-3, Ground Floor, Pamposh Enclave, Greater Kailash-I, New Delhi -110048 (A Unit of Classic Hospitality)		
2	Type of Occupancy	Group-D Assembly Building.		
3	Building Comprised of	Basement, Stilt, Ground + Three upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/SZ/2021/184 dated 16/04/2021		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	25/06/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Praveen Kumar (Manager)		
10	Year of construction	— Restt. at ground floor of the bldg.		
11	Applicant letter No.	MHA Portal ID 2023092716506 dated 31/05/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Required	09 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	Required	02 Nos	MR
	➤ Basement floor.	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floors	Required	1.28 & 1.50 m (Stilt to GF)	MR (old case)
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	Required	One	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	1.50 mtr each	2 mtr & 1.50 mtr	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	N/A	N/A
5	<b>Fire Extinguishers.</b>			
	• Total numbers	06 Nos	06 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI Marking	ISI marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A



N/A  
N/A  
N/A  
N/A  
IR  
A

	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 104 dated 15/03/2024.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/SZ/2021/184 dated 16/04/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*msk*

Signature of the Inspection Officer  
Name: Sh. Manoj Kumar Sharma  
Design: DO (South)

*26/6/24*  
Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

CFO (HQ)

*on leave*  
*Director*  
*27/6/24*

*As approved*

*As approved, F.T. letter is put up for your signature P1*

*Director*  
*11/7/24*

*msk*

*11/7/24*

*Uploaded*  
*02/7/24*  
*[Signature]*