



C-166

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/BNQT/WZ/2024/ 32

Dated: 28 / 06 / 2024

FIRE SAFETY CERTIFICATE

Certified that the M/s. Sawan Banquets (A unit of GS Hospitality Services), located at 54A/1, Ground & First floor, Rama Road, Najafgarh Road Industrial Area, New Delhi-110015, in a building comprised of Basement + Ground + 03 upper floors, was issued FSC by this department vide letter no. F6/DFS/MS/WZ/2021/262 dated 11/06/2021. The premises was re- inspected by the officer concerned of this department on 26/06/2024 in the presence of Sh. Sanjay Nagpal and observed that all the Fire Prevention and Fire safety arrangements provided in the building/premises found in good working condition & the owner have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" (Group- D) and validity upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions printed overleaf.

Issued on 28/06/2024 at New Delhi by.

(Atul Dang)
Director

Copy to: -

1. The Owner/ Occupier, M/s. Sawan Banquets (A unit of GS Hospitality Services), located at 54A/1, GF,FF, Rama Road, Najafgarh Road Industrial Area, New Delhi- 110015.
2. The Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 110027.
3. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

INSPECTION REPORT

1. Name & address of the building	Sawan Banquets (A unit of GS Hospitality Services), located at 54A/1, GF,FF, Rama Road, Najafgarh Road Industrial Area, New Delhi-110015.
2. Type of Occupancy	Assembly (Banquet Hall)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/WZ/2021/262 dated: 11/06/2021
5. Fire Safety directives letter No	N/A
6. Date of inspection	26/06/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Sanjay Nagpal
9. Year of Construction	2003 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2022050409351, 2024061209290 dated 13/06/2024

The said Banquet Hall is running at Ground & 1st floor in a Building comprised of Basement + Ground + 03 upper floors. (Basement for Storage, Ground & First floor banquet, Second Floor for Kitchen & office rooms. Third floor is Sealed/ Closed (Half Built))

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Clause 35 (6), Delhi Fire Service Act-2007	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 m	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.5 mts	2.0 mts & 1.58 mts	MR
	• Basements	1.5 mts	1.91mts & 1.64mts	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	2.0 mts	Hall Only	MR
	g. Door Size	2.0 mts	G.F = 2 x 220cm, F.F = 2 x 2 mts.	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	24 nos. CO ₂ , ABC type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30m 5mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required Required Required Required	Provided Provided at GF Provided Provided Provided	MR MR MR MR MR
8	MOEFA			
9	Public Address System.			
		Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required Required N/A	Provided Provided N/A	MR MR N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm 02 02	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR NR	NR NR	NR NR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA 900 lpm 40 mtr Required Required	450 LPM 40 MH NA NA NA NA NA NA NA 900 lpm & 180 lpm (Jockey) Provided Provided Provided	NA NA NA NA NA NA NA NA NA MR MR MR MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank 	N/A N/A Required Required	50,000 ltrs N/A Provided Provided	N/A N/A MR MR

	• Overhead Tank capacity	10,000 litres	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/WZ/2021/262 dated 11/06/2021, renewal under rule 35 of the Delhi Fire Service Rules 2010, is recommended.

38/A00/MN
29/6/2024

(Signature)
29/6/2024

(Signature)

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

317
27/6/2024

CFO - on leave
Director
20/6/24

(Signature)

Uploaded
09/7/24
(Signature)