



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/630

Dated: 08/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Kannada Senior Secondary School** (ID: 2026024) located at No. 3, Lodhi Estate, New Delhi-110003, having two blocks, A-Block (Secondary) comprised of ground & three upper floors & B-Block (Primary) comprised of ground & two upper floor, owned/occupied by Delhi Kannada Education Society (Regd.), was issued fire safety certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/546 dated 28/07/2021. The school was re-inspected by the officers concerned of this department on 27/06/2024 in the presence of Sh. Prashanth Kumar (Principal) of the school and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in according with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational**" (Group-B) with effect from 08/07/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08 / 07 / 2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Delhi Kannada Senior Secondary School (ID: 2026024) located at No. 3, Lodhi Estate, New Delhi-110003.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	Delhi Kannada Senior Secondary School at No. 3, Lodhi Estate, New Delhi-110003 (School ID: 2026024)		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	A Block: Ground + 3 Upper Floors, B Block: Ground + 2 Upper Floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/2021/SZ/546 dt. 28/07/2021		
6.	Fire Safety directives Letter No.	DOE Circular No. 262 - 362 Dt. 17/01/2005		
7.	Date of inspection	27/06/2024		
8.	Name of the Inspecting Officer	DO (SD) and ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Prashanth Kumar (Principal)		
10.	Year of Construction	1995		
11.	Applicant's letter No	Outdoor Diary No. 2781 dated 11/06/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	12m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 Nos each blk	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5m / 0.90m	A Blk: 1.55m each and B Blk: 1.2m & 1.5m (Iron)	MR
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01 each Blk	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1.0m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30ACPH	NA	NA
	• Upper floors	12ACPH	NA	NA
5.	Fire Extinguishers			
	• Total numbers	ISI marked	22 Nos	MR
	• Types		ABC & CO ₂	MR
	• ISI marking		Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Hose-Reel	01 each Blk	MR
	• Length of hose reel hose		30m	MR
	• Nozzle diameter		5mm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	100mm	Provided	MR
	• Number of hydrants per floor	01 each Blk	Provided	MR
	• Hose Box	01 each Blk	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	A Blk: 450 LPM and B Blk: 450 & 180 LPM	MR
	➤ Head of the pump	40m	40m each	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltr	10,000 Ltr in each bk	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2021/SZ/546 dated 28/07/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Manoj
01/7

Signature of the Inspecting Officer
Name: Manoj Kumar Sharma
Designation: DO (SD)

Santosh
28/06/24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

CFO (HQ)

Manoj
21/7/2024

Director

[Signature]
07/07/22
Amul/SJ

Sir,
F.T letter is put up for your sig. pl

Director
[Signature]
05/07/24

Santosh
05/07/24