



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

cl/14



No. F6/DFS/MS/2024/School/ 618

Dated: 03/07/2024

FIRE SAFETY CERTIFICATE

Certified that Delhi King's way Modern School located at Gali No-18-19, A-Block, West Kamal Burari, Delhi-110084. comprised of Ground floor only owned/ occupied by the Delhi King's way Modern School have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 25.06.2024 in the presence of Mr. Dilshad Khan (Manager) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class 'Group B Educational' with effect from ...03/07/2024... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 03/07/2024..... at New Delhi

(Atul Garg)
Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Manager, Delhi King's way Modern School located at Gali No-18-19, A-Block, West Kamal Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Delhi Kingsway Modern School at Gali No-18-19, A-Block, West Kamal Vihar, Burari, Delhi-110084.
2. Composition of building : Ground floor only
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 25.06.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Dilshad Khan (Manager)
10. Year of Construction : 2018
11. Applicant's letter No. : Online e-mail dated 24.06.2024

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.50m	4.50m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	01m	01m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	04nos	05nos	MR
	• Types	ABC/CO2	ABC-05	MR
	• ISI marking	ISI Marked	Yes	MR

(Handwritten marks)

N/5

6	First-Aid Hose Reels.					
	• Total numbers on each floor	NA	NA	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA	NA	NA
	• Nozzle diameter	NA	NA	NA	NA	NA
7	Automatic fire detection and alarming system.					
	• Type of detectors	NA	NA	NA	NA	NA
	• Location of Main Panel	NA	NA	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA	NA	NA
	• Alternate source of power	NA	NA	NA	NA	NA
	• Hooters' Location	NA	NA	NA	NA	NA
8	MOEFA			NA	NA	NA
9	Public Address System.			NA	NA	NA
10	Automatic Sprinkler System.					
	• Basement	NA	NA	NA	NA	NA
	• Upper Floor	NA	NA	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA	NA	NA
11	Internal Hydrants					
	• Size of riser/down-comer	NA	NA	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA	NA	NA
	• Hose Box	NA	NA	NA	NA	NA
12	Yard Hydrants.					
	• Total number of hydrants	NA	NA	NA	NA	NA
	• Hose Box	NA	NA	NA	NA	NA
13	Pumping Arrangements.					
	• Ground Level					
	➤ Discharge of main Pump	N/A	N/A	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A	N/A	N/A
	• Terrace level					
	➤ Discharge of pump	NA	NA	NA	NA	NA
	➤ Head of the pump	NA	NA	NA	NA	NA
	➤ Power Supply	NA	NA	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA	NA	NA
14	Captive Water Storage for fire fighting.					
	• Underground tank capacity	NA	NA	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA	NA	NA
	➤ Access to tank	NA	NA	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA	NA	NA
15	Exit Signage.			NA	NA	NA
16	Provision of Lifts.			NA	NA	NA

	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	Total Area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/School/292 dated 28.05.2024.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by Director of Education dated 01.03.2011, it is recommended to grant Fire Safety Certificate

Signature of the Inspecting Officer
 Name :-C.L. Meena
 Designation:- ADO/RN

DO(NW)

 26/06/2024

By ufo (2024)

dy
 26/6

cf - on leave
 Director

 27/6/24

Am4 R.12

DCFO/23-NW...
 Dated...26.06.24..

Conf. P.T.O .