

c/62

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2024/School/WZ/ 612

Dated: 03/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Co-ed, Sr. Sec. School, Sector-15, Rohini, Delhi-110089, (School ID-1413071), comprised of Ground + Three upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2021/934 dated 12.11.2021. The premises was re-inspected by the officer concerned of this department on 21.06.2024 in the presence of Dr. Reena Dagar (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 03/07/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/07/2024 at New Delhi by

  
 (Atul Garg)  
 DIRECTOR

Ph: 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Govt. Co-ed, Sr. Sec. School, Sector-15, Rohini, Delhi-110089,(School ID-1413071).

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)



**INSPECTION REPORT**

School ID-1413071

1. Name & address of the building : Govt. Co-ed, Sr. Sec. School, Sector-15, Rohini, Delhi-110089.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + 03 upper floor)
4. Details of Previous NOC : F.6/DFS/MS/School/WZ/2021/934 dated 12.11.2021.
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 21.06.2024
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers  
From the building side : Dr. Reena Dagar (Principal)
9. Year of Construction : 2007
10. Applicant's letter No. : Online e-mail dated 21.10.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	Accessible	MR
		Accessible	5.0m	MR
		NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02nos.	02nos.	MR
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.5m	1.6m x 2	MR
		NA	NA	NA
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.5m	2.10m	MR
	f. Door Size	1.20m	Provided	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA	NA	NA
		12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI marking</li> </ul>	10nos.	10nos.	MR
		ABC/CO2	ABC-10	MR
		ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	02nos.	Provided	MR
		30mm	Provided	MR
		5m	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

Raj





PA System Panel	NA	NA	NA
Battery backup	NA	NA	NA
Building Floor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

NA  
NA  
NA  
NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/WZ/2021/934 dated 12.11.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*Ajay Kumar Sharma*  
20/6/24

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

~~DO (NO)~~  
Dy. CFO/WZ

*Ajay Kumar Sharma*  
25/10/2024

*Ajay Kumar Sharma*  
26/6/2024

01...1059...  
ad. 26/06/24...

Cfo - on leave  
Director *Ajay Kumar Sharma*  
27/6/24

*Any letter*

FT letter is put up for kind perusal and signature please.

*Ajay Kumar Sharma*  
28/6/24

Director *Ajay Kumar Sharma*  
27/6/24

*m*