

c/09



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2024/School/ 616

Dated: 03/07 /2024

**FIRE SAFETY CERTIFICATE**

Certified that **Heaven Public School** located at **B- Block, Gali No-66, 25 Foota Road Sant Nagar, Burari, Delhi-110084**. comprised of ground & 03 upper floors but school is running at ground & first floor only owned/ occupied by the **Heaven Public School** have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **25.06.2024** in the presence of **Sh. Jitendar Kumar (Attendant)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class '**Group B Educational**' for **ground & first floor only** with effect from **...03/07/2024...** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **03/07/2024**..... at New Delhi

  
(Atul Garg)  
Director  
Ph:-011-23414000  
etc Rep

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Manager, Heaven Public School located at B- Block, Gali No-66, 25 Foota Road Sant Nagar, Burari, Delhi-110084.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Heaven Public School at B- Block, Gali No-66, 25 Foota Road, Sant Nagar, Burari, Delhi-110084.
2. Type of Occupancy : Educational
3. Composition of building : Ground & 03 upper floors **but school is running at ground & first floors only**, 2<sup>nd</sup> & 3<sup>rd</sup> floor is being used for residential purpose.
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Director of education circular dated 01.03.20211
7. Date of inspection : 25.06.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
from the building side : Sh. Jitendar Kumar (Attendant)
10. Year of Construction : 2006
11. Applicant's letter No. : Online E-mail Dated 14.06.2024

Minimum Standards on fire prevention and fire safety U/R 33	Director of education circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
<b>1. Access to building</b>			
• Road width	4.50m	Provided	MR
• Gate width	Directly accessible	Directly accessible	MR
• Width of internal road	NA	NA	NA
<b>2. Number, Width, Type &amp; Arrangement of Exits.</b>			
<b>a. Number of staircases</b>			
• Upper Floors	01	01	MR
• Basements	NA	NA	NA
<b>b. Width of staircases</b>			
• Upper Floors	1.50m or less and 75cm	1.50m	MR
• Basements	NA	NA	NA
<b>c. Protection of exits</b>			
• Fire check door	NA	NA	NA
• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA
e. Width of Corridor	NA	NA	NA
f. Door Size	1.0m	1.0m	MR
<b>3. Compartmentation.</b>			
• Fire check door	NA	NA	NA
• Sealing of electrical shafts	NA	NA	NA
• Fire Rating of shaft door	NA	NA	NA
• Water Curtain	NA	NA	NA
• Fire Dampers	NA	NA	NA
<b>4. Smoke Management System.</b>			

*[Handwritten signature]*

	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA	NA	NA
		NA	NA	NA
5	<b>Fire Extinguishers</b>		04nos	MR
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	04nos ABC/Co2	04nos ABC-04	MR
		Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			

	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	NA	NA	NA
15	<b>Exit Signage.</b>	NA	NA	NA
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by Director of Education dated 01.03.2011, it is recommended to grant Fire Safety Certificate

Signature of the Inspecting Officer  
 Name :- C.L. Meena  
 Designation :- ADO/RN

DO(NW)

26/06/2024

By C/O (NW)

26/6

C/O - on leave

Director 21/06/24

ADO/RN

DCFO/07...N/A  
 Dated: 26/06/24

cont. --- P.T.O.