



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 619

Dated: 03/07/2024

FIRE SAFETY CERTIFICATE

Certified that **New Era Public School** located at **Khasra No- 101/17, West Kamal Vihar, Kamalpur, Burari, Delhi-110084**. comprised of **Ground & first floor only** owned/ occupied by the **New Era Public School** have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **25.06.2024** in the presence of **Mr. Ritesh Gosain (Manager)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class '**Group B Educational**' with effect from ...**03/07/2024**.. for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ...**03/07/2024**.. at New Delhi

(Atul Garg)

Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Manager, New Era Public School located at Khasra No- 101/17, West Kamal Vihar, Kamalpur, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : New Era Public School at Kh. No- 101/17, West Kamal Vihar, Kamalpur, Burari, Delhi-110084.
2. Composition of building : Ground & first floor only
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 25.06.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Ritesh Gosain (Manager)
10. Year of Construction : 2018
11. Applicant's letter No. : Online e-mail dated 18.06.2024


	Minimum Standards on fire prevention and fire safety U/R 33	Director of education circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	Directly accessible	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m or less and 75cm	1.50m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	03nos	03nos	MR
	• Types	ABC/CO2	ABC-03	MR
	• ISI marking	ISI Marked	Yes	MR

N/S					
6	First-Aid Hose Reels.		NA	NA	NA
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		NA	NA	NA
			NA	NA	NA
			NA	NA	NA
7	Automatic fire detection and alarming system.		NA	NA	NA
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
8	MOEFA		NA	NA	NA
9	Public Address System.		NA	NA	NA
10	Automatic Sprinkler System.		NA	NA	NA
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 		NA	NA	NA
			NA	NA	NA
			NA	NA	NA
11	Internal Hydrants		NA	NA	NA
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 		NA	NA	NA
			NA	NA	NA
			NA	NA	NA
12	Yard Hydrants.		NA	NA	NA
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		NA	NA	NA
			NA	NA	NA
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
	NA	NA	NA		
14	Captive Water Storage for fire fighting.		NA	NA	NA
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
15	Exit Signage.		NA	NA	NA
16	Provision of Lifts.				


	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/School/293 dated 28.05.2024.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by Director of Education dated 01.03.2011, it is recommended to grant Fire Safety Certificate


 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

DO(W)


 26/06/2024
 Dy I/O (W2)


 P.S/G


CFO/20-N/2024
 dated 26/06/24

CFO - on leave

 Director


 ADO/RN

As approved, F.S. letter is setup for your signature pl.


 27/07/2024