

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/8  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2024/ 607

Dated:- 03/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Ram Singh Memorial Public School** Located at **RZF-1/A, Nihal Vihar, Nangloi, Delhi-110041**, comprised of **Ground Floors only** owned/occupied by **Ram Singh Memorial Public School**, was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/2018/WZ/1029 dated 11/05/2018**. The said premises was re-inspected by the officer concerned of this department on 27/06/2024 in the presence of Sh. Hemant Kumar (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E. Cr. No. 3298-3398 dated 01/03/2011 and that the premises/building is fit for occupancy class "**Educational Building**" **Group B** with effect from **03/07/2024** for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on **03/07/2024** at New Delhi by.

(Atul Garg)  
Director

Tel No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Ram Singh Memorial Public School, RZF-1/A, Nihal Vihar, Nangloi, Delhi-110041.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name and address of the building: **Ram Singh Memorial Public School** located at **RZF-1/A, Nihal Vihar, Nangloi, Delhi-110041**
2. Type of Occupancy : Educational (Ground Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/WZ/1029 Dated 11/05/2018
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 27/06/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Sh. Hemant Kumar (Manager)
9. Year of Construction : 2000
10. Applicant's letter No. : nil dated 20/06/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 3298-3398 dated 01.03.2011/as per FSC dated 11/05/2018		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	06 m	Provided		MR
	• Gate width	4.5 m	Provided		MR
	• Width of internal road	NA	NA		NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	NA	NA		NA
	• Basements	NA	NA		NA
	b. Width of staircases				
	• Upper floors	NA	NA		NA
	• Basements	NA	NA		NA
	c. Protection of exits				
	• Fire check door	NA	NA		NA
	• Pressurization	NA	NA		NA
	d. No of continuous staircase to terrace	NA	NA		NA
	e. Width Of Corridor	1.0 m	Provided		MR
	f. Door Size		NA		
3.	Compartmentation				
	• Fire check door	NA	NA		NA
	• Sealing of electrical shafts	NA	NA		NA
	• Fire Rating of shaft door	NA	NA		NA
	• Water Curtain	NA	NA		NA
	• Fire Dampers	NA	NA		NA
4.	Smoke managements System				
	• Basements	NA	NA		NA
	• Upper floors	NA	NA		NA
5.	Fire Extinguishers				
	• Total numbers	02 nos.	06 nos.		MR
	• Types	ABC & CO <sub>2</sub>	Provided		MR
	• ISI marking	ISI Marked	Provided		MR

6.	First – Aid Hose Reel			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19. Fire control room			
<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2018/WZ/1029 Dated 11/05/2018 is recommended.

Accordingly DFA is prepared for approval & signature please

~~DCFO (WZ)~~

~~Q11TH 11/28/06/24~~

Aman Kumar Lathar  
ADO (JWP)

~~dy 28/6~~

CFO - On leave  
~~Director 28/06/24~~  
~~Amu/BWP~~

~~25/06/24~~  
~~28/06/2024~~

Sis, F.T. letter is added for your signature pl.

~~Director 11/07/24~~

~~Q11TH 11/07/24~~  
~~Amu (JWP)~~

~~M~~