

2/21

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/2024/SZ/School/633

Dated: 08/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Ramjas Primary School, Located at Anand Parbat, New Delhi - 110005 (School ID-2160328) comprised of Ground Floor was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/School/2021/SZ/403 dated 28/06/2021. The premises was inspected by the officer concerned of this department on 04/07/2024 in the presence of Ms. Shruti Dhingra (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with the DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class B "Educational building" with effect from 08/07/2024 for a period of three years, subject to condition given below.

Issued on 08/07/2024.... at New Delhi by.

  
(Atal Garg)  
Director  
Delhi Fire Service.

Copy to:

1. The Principal, Ramjas Primary School, Located at Anand Parbat, New Delhi - 110005 (School ID-2160328).
2. The Directorate of Education Old Secretariat Delhi - 110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/17

**INSPECTION REPORT**

1. Name & address of the building: Ramjas Primary School, Located at Anand Parbat, New Delhi - 110005 (School ID-2160328)
2. Type of Occupancy : Educational (Ground Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2021/SZ/403 dated 28/06/2021
5. Fire Safety directives L. No. : DOE Circular 3298 -3398 Dated 01/03/2011
6. Date of inspection : 04/07/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer from the building side: Ms. Shruti Dhingra (Principal)
9. Year of Construction : 1960
10. Applicant's letter No. : DFS Outdoor diary No. 2496 dated 05/06/2024

No. of Students=490
No. of class rooms=15
Plot area=3341m <sup>2</sup>
Covered area=1278 m <sup>2</sup>

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/14, N/15 & N/16	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	6 mtr	MR
	• Gate width	4.5mtrs	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA



N/19

15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no: F.6/DFS/MS/School/2021/SZ/403 dated 28/06/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved the FSC may be issued.

Signature of the Inspecting Officer  
 Name *Uday Kir Singh*  
 Designation *ADDO/DW/14*

*DO/SO*  
*AD/SO*  
*CFO/SO*  
*Director*  
*3/7/21*  
*M*