

130

FORM 'H'
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
 NEW DELHI

No.F6/DFS/MS/2024/SZ/ 615

Dated: 03/07/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Ramjas Sr. Sec. School No. 5 Located at Karol Bagh, New Delhi - 110005 comprised of Ground + One Upper Floor was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/School/2021/SZ/416 dated 01/07/2021. The premises was inspected by the officer concerned of this department on 21/06/2024 in the presence of Dr. Sandeep Gupta (Principal) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class B "Educational building" with effect from 03/07/2024 for a period of three years, subject to condition given below.

Issued on ... 03/07/2024 ... at New Delhi by.


 (Atul Garg)
 Director
 Delhi Fire Service
 o/c 

Copy to:

1. The Principal Ramjas Sr. Sec. School No. 5 Located at Karol Bagh, New Delhi - 110005.
2. The Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2) Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3) The trained staff should be available round the clock.
- 4) Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5) The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6) The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7) Basement shall be used strictly as per building bye laws.
- 8) he owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Ramjas Sr. Sec. School No. 5 Located at Karol Bagh, New Delhi - 110005
2. Type of Occupancy : Educational (Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2021/SZ/416 dated 01/07/21
5. Fire Safety directives L. No. : DOE Circular 3298 -3398 Dated 01/03/2011
6. Date of inspection : 21/06/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side: Dr. Sandeep Gupta (Principal)
9. Year of Construction : Before 1938
10. Applicant's letter No. : Email dated 23/05/2024

No. of Students=731
No. of class rooms=21
Plot area=10500 m ²
Covered area=7500 m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/15, N/16 & N/17	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	6 mtr	MR
	• Gate width	4.5mtrs	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	2 No's	3 No's	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 m	2X1.35m & 0.79m	MR (Being old case)
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	01
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	Sealed	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR

V/D

N/19

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 Nos. ABC & CO ₂ ISI marked	Provided ABC Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
15	Exit Signage	Required	Provided	MR

N/20

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC Fire Extinguisher provided near electric meter	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F.6/DFS/MS/School/2021/SZ/416 dated 01/07/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved the FSC may be issued.

Signature of the Inspecting Officer

Name *Uday Kir Singh*

Designation *ASO/DWR*

[Signature]
11/7/24

[Signature]
CFo (S2)
21/7/2024

[Signature]
Director
21/07/24