

C79

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2024/ 275

Dated 08/07/2024

FIRE SAFETY CERTIFICATE

Certified that the Richmond Inn Guest House at 9597-9603, Sadar Thana Road, Motia Khan, Pahar Ganj New Delhi comprised of Ground + 04 Upper floors, Ground floor (reception + 01 office), 1st floor (09 guest rooms), 2nd floor (10 guest rooms), 3rd floor (10 guest rooms), 4th floor not in use as per affidavit dated 27.12.2019, total 29 guest rooms upto third floor owned/occupied by Richmond Inn Guest House was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2021/343 dated 26/08/21 up to third floor only. Now, the premise was re-inspected by the officer concerned of this department on 26/06/24 in the presence of Manager and found that the said guest house building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential, Sub Division-A-1" Ground floor (reception + 01 office), 1st floor (09 guest rooms), 2nd floor (10 guest rooms), 3rd floor (10 guest rooms) total - 29 guest rooms up to third floor only and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued08/07/2024.....New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, North MCD, Civic Centre, New Delhi. To kindly ensure the occupancy as detailed above and deviation if any.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID No. 2024060809046 dated 08/06/24.
3. The Manager, Richmond Inn Guest House 9597-9603, Sadar Thana Road, Motia Khan, Pahar Ganj, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited. Further ,4th floor shall not be used for any purpose.

N/35
INSPECTION REPORT

1. Name & address of the building Richmond Inn Guest House at 9597-9603, Sadar Thana Road, Motia Khan, Pahar Ganj New Delhi.
2. Type of occupancy:- Gr. + 04 Upper floors (total 29 Guest rooms) Ground floor (reception + 01 office), 1st floor (09 guest rooms), 2nd floor (10 guest rooms), 3rd floor (10 guest rooms), 4th floor (staff kitchen) not in use as per affidavit dated 27.12.2019
3. Type of case:- Renewal
4. Details of previous NOC:- No.F6/DFS/MS/GH/NDZ/2021/343 dated 26/08/21
5. Fire safety directives No.- N/A
6. Date of inspection: - 26/06/24
7. Name of the inspecting officer: - Sh. Ravinder Singh ADO/CC)
8. Name & designation of officer
From the building side: - Manager
9. Year of construction: - 2008
10. Applicant's letter No: - ID No. 2024060809046 dated 08/06/24.
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	09 mtr. ✓	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No.	01 No. ✓	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 mtr.	1.22 to 1.25 Mtr. ✓	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		01	01	MR
	E. Width of corridor			
		N/A	N/A	N/A
	F. Door size			
		01 mtr.	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	08	08	MR

e b

N/36


	2) Types	ABC & CO2	ABC & CO2 /	MR
	3) ISI marking	Required	Provided /	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01 /	MR
	2) Length of hose reel hose	30 mtr.	30 mtr. /	MR
	3) Nozzle diameter	05 mm	05 mm /	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO type	Required	Provided /	MR
	2) Location of main panel	Gr. floor	Provided /	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided /	MR
	5) Hooter's Location	Gr. floor	Provided /	MR
8.	MOEFA	Required	Provided /	MR
9.	Public Address System	Required	Provided /	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM /	MR
	b) Head of pump	30 mtr.	30 mtr. /	MR
	c) Power supply	Required	Provided /	MR
	d) Auto starting of pump	Required	Provided /	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltr.	2500 ltr. /	MR

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2021/343 dated 26/08/21, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.


Signature of the Inspecting Officer




Name: - Ravinder Singh
Designation: - ADO (CC)


DO/CD



17/24
~~Dy. C.O. (NDZ)~~



02/07/24

C.F.O.

3/7/2024

Director 
21/7/24
ADCC

Approved for put up for kind perusal
Supervisor 
5/7/24

Director 
5/7/24


5/7/24