

No. F6/DFS/MS/School/NDZ/2024/ 627

Dated: 04/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **Rishabh Public School**, located at **Pocket-IV, Mayur Vihar, Phase-1, Delhi - 110091** comprised of **A block (G+2 upper floors) & B block (B+G+3 upper floors)** owned/occupied by **Rishabh Public School** was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/NDZ/2021/689 dated 02/09/2021. The School building was re-inspected by the officer concerned of this department on 25.06.2024 in presence of Mr. N.S. Bhati (Chairman) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education and the school building is fit for occupancy class "**Educational Building**" (**Group-B**) **Sub - Div. B-1** with effect from 04/07/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions printed below.

Issued on 04/07/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, D-Block, Anand Vihar, Delhi - 110091.
2. The Chairman, Rishabh Public School, located at Pocket - IV, Mayur Vihar, Phase-1, Delhi - 110091.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used as per NBC/UBBL.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Rishabh Public School, located at Pocket-IV, Mayur Vihar, Phase-1, Delhi - 110091.		
2	Building is comprised of	A Block (G +2) & B Block (B+G+3) upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/689 dated 02/09/2021.		
6	Fire safety directives letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
7	Date of inspection	25.06.2024.		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. N.S. Bhati (Chairman)		
10	Year of construction	2002		
11	Applicant's letter no.	Outdoor Dairy No.2907 dated 12/06/2024		
S.No	Minimum standard of fire safety requirements as per circular no.262-362 dated 17.01.2005	Requirement Circular	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	10 mtrs. ✓	MR
B	Gate width	4.5 mtrs	05 mtrs	MR
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases	04 nos.	04 nos. ✓	MR
	1. Upper floor A Block	02 nos.	02 nos. ✓	MR
	B Block	02 nos	02 nos	MR
	2. Basement in B Block only	01 no.	01 no. ✓	MR
B	Width of staircases			
	1 Upper floor A Block (G+2)	1.25 mtrs	1.25 mtrs & 1.15 mtrs ✓	MR
	B Block (G+3)	1.50 mtrs	1.50 mtrs each ✓	MR
	2. Basement in B Block only	1.50 mtrs	1.50 mtrs ✓	MR
C	Protection of exits			
	1 Fire check door	N/A	N/A	N/A
	2 Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	02 nos.	03 nos. ✓	MR
E	Width of corridor	1.50 mtrs.	1.50 mtrs. ✓	MR
F	Door size	1.0 mtrs.	1.0 mtrs. ✓	MR
3	Compartmentation:			
A	Fire check door	Required	Provided	MR
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	Required	Provided ✓	MR
B	Upper floors	N/A	Ventilated ✓	MR

5. Fire Extinguisher:				
A	Total numbers	10 nos.	12 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
6. First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no	01 no	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	5 mm	5 mm	MR
7. Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	Provided	MR
9	Public Address System:	N/A	Provided	MR
10. Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 no	01 no	MR
C	Hose box	01 no	01 no	MR
12. Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13. Pumping Arrangements:				
1. Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2. Terrace Level				
A	Discharge of pump	450 LPM	2 X 450 LPM	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	50,000 liters	MR
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	10,000 liters	15,000 liters	MR
		Required	Provided	MR
15	Exit Signage:			
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/NDZ/2021/689 dated 02/09/2021 under the Circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 is recommended to be renewed.

No file is pending with me before disposal of this case.



27/6/2024

Signature of the Inspecting Officer

Name: - Yashwant Singh Meena

Designation: - ADO (L.N)

~~DY.CFO (NDZ)~~

C.F.O.

Directed

2/7/2024

3/7/24

ADOLN

Kiv P
28/06/24