

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No.F.6/DFS/MS/BNQT/2024/SZ/34

Dated: 08/07/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Silver Grand Banquet is running at second floor only building comprised of lower basement, upper basement, ground floor plus four upper floors located at S-26 (Part), Second Floor, Ivory Tower, Old Ajanta Cinema Complex, Ajay Enclave, Subhash Nagar, New Delhi, owned/occupied by M/s Silver Grand Banquet was issued FSC by this department vide letter no. F6/DFS/MS/BNQT./2021/SZ/530 dated 27.10.2021. The banquet hall was re-inspected by the officers concerned of this department on 28.06.2024 in the presence of Sh. Yaddu Mohan Mittal (MD) and found that the Banquet have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (Second floor Only) is fit for occupancy class Group-D "Assembly Building"(Banquet Hall) w.e.f. 08/07/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 08/07/2024 at New Delhi.



(Atul Garg)
Director

Delhi Fire Service

Online application Id 2024040103927 dated 06.06.2024

Following fire safety directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/A

INSPECTION REPORT

1. Name & address of the building: M/s Silver Grand Banquet, S-26 (Part), Second Floor, Ivory Tower, Old Ajanta Cinema Complex, Ajay Enclave, Subhash Nagar, New Delhi.
2. Building is comprised of : Lower basement, upper basement, Ground floor plus four upper floors but banquet hall is running at second floor only
3. Type of Occupancy : Group D (Assembly Building)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/BNQT./2021/SZ/530 dated 27.10.2021.
6. Fire Safety directives letter No : F6/MS/DFS/BP/2004/1973 dated 31.08.2004
7. Date of inspection : 28.06.2024
8. Name of Inspecting Officers : D.O VEDPAL CHHIKARA & A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Yaddu Mohan Mittal (MD)
10. Year of Construction : 2010-2011
11. Applicant's letter No. : Application Id No. 2024040103927 dated 06.06.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 m 06 m N/A	Provided Provided N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	05 no.'s 03 no.'s & 01 ramp	Provided 03 no.'s & 02 ramps	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	2.0 & 1.50 m 1.50 m	1X2.0 M & 4X 1.50 M 1X2.0, 2X 1.50 m & 02 ramps	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required Required	Provided Provided	MR MR
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.50 m	2.05 m	MR
	f. Door Size	2.0/1.50/1.0 m	2.0, 1.50, 1.60 & 1.40 m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required N/A N/A N/A	Provided Sealed N/A N/A N/A	MR MR N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	Required Required	Provided Provided	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	14 No.'s ABC/CO ₂ ISI marked	Provided Provided Provided	MR MR MR

to

h

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers 	Two	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	Smoke	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	G Floor	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Nr. Main gate	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Ground Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants 	Two	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Two	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	09 no.'s	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	09 no.'s	Provided	MR
13.	Pumping Arrangements (Common with whole premises)			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	2850 LPM	Provided	MR
		60 m	Provided	MR
		Two	Provided	MR
		450 LPM	Provided	MR
		60 m	Provided	MR
		2850 LPM	Provided	MR
		60 m	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM	Provided	MR
		30 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	2,00000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR

(Handwritten marks)

N/30

MR	MR	MR	Required	Provided	M/R
15.	Exit Signage.				
16.	Provision of Lifts.				
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 		N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
17.	Standby power supply		Required	Provided	M/R
18.	Refuge Area.				
	<ul style="list-style-type: none"> Total Area Location 		N/A	N/A	N/A
			N/A	N/A	N/A
19.	Fire Control Room				
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 		N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:		N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/GH/2019/BNQT./SZ/286 dated 05/02/2019, renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

Vedpal 5/17/24
 Signature of the Inspecting Officer
 Name Vedpal Chhikara
 Designation : Divisional Officer (SW)

R. K. Yadav 4/17/2024
 Signature of the Inspecting Officer
 Name : R. K. Yadav
 Designation : ADO(JKP)

CFO(S2) *Vijay*
 5/17/2024
~~Director~~ *(Signature)*
 5/17/24
(Signature)

Uploaded
 08/17/24

(Signature)