



75  
जाज़ादी  
अमृत महोत्सव  
C/42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No: F.6/DFS/MS/School/WZ/2024/ 617

Dated: 03 / 07 / 2024

**FIRE SAFETY CERTIFICATE**

Certified that the S.M. Arya Public School located at Punjabi Bagh (West), New Delhi – 110026. Comprised of basement, ground & 02 upper floors. Owned/occupied by S.M. Arya Public School, has already issued Fire safety Certificate Vide letter No. F.6/DFS/MS/School/WZ/2020/462 dated 03/11/2020. The premises was re-inspected by the officer concerned by this department on 18/06/2024 in the presence of Sh. Captain Laxmi Narayan (Caretaker) and observed that all the fire prevention and fire safety arrangements provided in the building/premises found in good working condition. The premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the DOE Circular No. 262-362 dated 17/01/2005/NBC(Part-IV) and that the premises is fit for occupancy class “Educational” (Group-B), with effect from ...03/07/2024... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

Issued on ...03/07/2024... at New Delhi.

(Atul Garg)  
Director

Copy to: -

1. The Principal, S.M. Arya Public School located at Punjabi Bagh (West), New Delhi – 110026.
2. Director of Education, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. Basement shall be used as per building bylaws.



## INSPECTION REPORT

1. Name & address of the building : S.M. Arya Public School located at Punjabi Bagh (West), New Delhi – 110026.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/WZ/2020/462 dated 03/11/2020.
5. Fire Safety directives letter No : DOE Circular dated 17/01/2005 / NBC Part - IV
6. Date of inspection : 18/06/2024
7. Name of the Inspecting Officers : Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side : Sh. Captain Laxmi Narayan (Caretaker)
9. Year of Construction : 1983-84 (As per prev. insp. report dated 26/10/2020)
10. Applicant's letter No. : Letter No.- D/VI/05/2024 dated 22/05/2024

Total Plot Area – 3 Acre
Total Covered Area – 5472m <sup>2</sup> approx
Area of Basement – 40 yard <sup>2</sup>

\* The said school is running in Two Blocks, B-1=Ground + 02 upper floors & B-2 = Ground + 1 upper floor (Nursery wing) both are inter connected & Basement (approx 40 yard<sup>2</sup>) near assembly ground.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mtr	Provided	MR
	• Gate width	05 mtr	Provided	MR
	• Width of internal road	As per section plan	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	03	05 provided	MR (Covered area of each floor is 1800 m <sup>2</sup> approx)
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floors	1.5 mts	1.45m x 1, 1.60m x 1, 1.30m x 1, 1.10m x 2	MR
	• Basements	1.00 mtr	1.10m x 2 (area 40 yard <sup>2</sup> & being used for storage purpose & separate from school building)	MR (Old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	02 Provided	MR
	f. Width of Corridor	1.5 mts	Provided	MR
	g. Door Size	1 mtr	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	35 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR



6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	Provided	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	NR	02	NR
	• Hose Box	NR	02	NR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM & 180 LPM	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	25,000 ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

BT

Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA
	• Pressurization of Lift lobby	NA	NA
	• Communication In lift Car	NA	NA
	• Fireman's Grounding Switch	NA	NA
	• Lift Signage	NA	NA
17	Standby power supply	Required	Provided
18	Refuge Area.		
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19	Fire Control Room		
	• Detector System Panel	NA	NA
	• Flow Switch Panel	NA	NA
	• PA System Panel	NA	NA
	• Batter backup	NA	NA
	• Building Floor Plans	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA

The Fire protection system provided in the building were checked and found functional at time of inspection. The shortcoming issued by this department vide letter No. F6/DFS/MS/School/WZ/2024/02 dated 03/01/2024 has been complied.

In view the deemed compliance of the minimum standards on Fire Prevention and fire safety required under the rules, NOC/FSC issued vide letter No.- F.6/DFS/MS/School/WZ/2020/462 dated 03/11/2020 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

13/ADO/MN  
24/6/24

XFO/196-LSD  
dated 26/6/24

Cfo - on leave

Director

ADY/MN

Sir, F.T is put up for your kind personal & dig please.

*[Signature]*  
24/6/2024  
Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (MN)

*[Signature]*  
01/7/2024