

C72

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/School/2024/ 620

Dated: 04/07/2024

FIRE SAFETY CERTIFICATE

Certified that **The Sovereign School, Pkt-17, Phase-III, Sector-24, Rohini, Delhi-85**, comprised of **Basement + Ground + Four upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2021/WZ/355** dated **04.05.2021**. The premises was re-inspected by the officer concerned of this department on **21.06.2024** in the presence of **Sh. R. N. Jindal (Owner)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Rule 33 of the Delhi Fire Service Rules, 2010 and the building premises is fit for occupancy of **Group Class B (Educational)** with effect from 04/07/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/07/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54
2. The Principal, The Sovereign School, Pkt-17, Phase-III, Sector-24, Rohini, Delhi-85.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

INSPECTION REPORT

1. Name & address of the building : The Sovereign School, Pkt-17, Phase-III, Sector-24, Rohini, Delhi-85
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal (Basement + Gr. + 04 upper floors)
 4. Details of Previous NOC : F.6/DFS/MS/2021/WZ/355 dated 04.05.2021
 5. Fire Safety directives letter No : F.6/DFS/MS/BP/2007/3193 dated 25.10.2007
 6. Date of inspection : 21.06.2024
 7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
 8. Name and designation of officers
 From the building side : Sh. R. N. Jindal (Owner)
 9. Year of Construction : 2007
 10. Applicant's letter No. : OD No.2352 dated 03.06.2024.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Rule 35(6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04nos.	04nos.	MR
	• Basements	04nos.	04nos.	MR
	b. Width of staircases			
	• Upper Floor	1.5m	Provided	MR
	• Basements	1.5m	Provided	MR
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01nos.	02nos.	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	Required	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	40nos.	40nos.	MR
	• Types	ABC/CO2	ABC/CO2/Wco2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

mg

ly

	• Hooters' Location	NA	NA	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	03	Provided	MR
	• Hose Box	03	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	180lpm	180lpm	MR
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900lpm	900lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	75,000ltr	75,000ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25,000ltr	25,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2021/WZ/355 dated 04.05.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay Kumar Sharma
24/6/24

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Do(NW)

[Signature]
25/04/2024

Dy. CFO(WZ)

[Signature]
26/6/2024

DCFO: 1065

Dated: 26/6/2024

CFO - on leave

Director

[Signature]
28/6/24

[Signature]
28/6/24

FT letter is put up for kind perusal and signature please.

Director

[Signature]
27/7/24

[Signature]
27/7/24