



**FIRE SAFETY CERTIFICATE**

Certified that the **B.R.Model Public School** located at **B-209 Gali No.1, Rajveer Colony, Gharoli, Extn. Delhi-110096**, comprised of **ground plus one upper floor** owned/occupied by **B.R.Model Public School**, was issued Fire Safety Certificate by this department vide letter No. **F6/MS/DFS/06/1745 dated 28/07/2006**. The School building was re-inspected by the officer concerned of this department on 02/07/2024 in presence of Mr. Prince Sharma (Manager) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular letter No. 262-362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building"** with effect from 09/07/2024 for a period of **three years**, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 09/07/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
o/c DELHI FIRE SERVICE

**Copy to:-**

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi-110053.
2. The Principal, B.R.Model Public School located at B-209 Gali No.1, Rajveer Colony, Gharoli, Extn. Delhi- 110096.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/03

## INSPECTION REPORT

1	Name & address of the building		B.R.Model Public School Gali No.1, Rajveer Colony, Gharoli, Ext. Delhi-110096			
2	Building is comprised of		Ground plus one upper floor			
3	Type of occupancy		Educational Building			
4	Type of case		Renewal			
5	Details of previous FSC		F6/MS/DFS/06/1745 dated 28/07/2006			
6	Fire safety directives letter no.		Circular No. 262 - 362 dated 17/01/2005			
7	Date of inspection		02/07/2024			
8	Name of the inspecting officers		Yashwant Singh Meena ADO (L.N)			
9	Name of the designation of officer from the building side		Mr. Prince Sharma(Manager)			
10	Year of construction		2003			
11	Applicant's letter no.		Outdoor Diary No.3172 Dated 20/06/2024			
S.No	Minimum standard of fire prevention and fire safety U/R 33		Circular Requirement	Provided at site	Remarks MR/NMR	
1	Access to Building:					
	A	Road width	6.0 mtrs.	6.0 mtrs.	MR	
	B	Gate width	N/A	N/A	N/A	
	C	Width of internal road	N/A	N/A	N/A	
2	Number, Width, Type and Arrangement of Exits:					
	A	Number of staircases				
		a	Upper floor	01 nos.	01 nos.	MR
		b	Basement	N/A	N/A	N/A
	B	Width of staircases				
		a	Upper floor	Required	1.20 mtrs	MR (old case)
		b	Basement	N/A	N/A	N/A
	C	Protection of exits				
		a	Fire check door	N/A	N/A	N/A
		b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace		01 no.	01 no.	MR
	E	Width of corridor		1.50 mtrs.	1.50 mtrs	MR
	F	Door size		1.0 mtr.	1.0 mtr	MR
3	Compartmentation:					
	A	Fire check door		N/A	N/A	N/A
	B	Sealing of electrical shafts		N/A	N/A	N/A
	C	Fire rating of shaft door		N/A	N/A	N/A
	D	Water curtain		N/A	N/A	N/A
	E	Fire dampers		N/A	N/A	N/A
4	Smoke Management System:					
	A	Basement		N/A	N/A	N/A
	B	Upper floor		N/A	N/A	N/A

<b>5</b>	<b>Fire Extinguisher:</b>			
<b>A</b>	Total numbers	06 nos.	10 nos.	MR
<b>B</b>	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
<b>C</b>	ISI marking	ISI marked	ISI marked	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>			
<b>A</b>	Total numbers of each floor	N/A	01 no	MR
<b>B</b>	Length of hose reel hose	N/A	30 mtr	MR
<b>C</b>	Nozzle diameter	N/A	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>			
<b>A</b>	Type of detectors	N/A	N/A	N/A
<b>B</b>	Location of main panel	N/A	N/A	N/A
<b>C</b>	Location of repeater panel	N/A	N/A	N/A
<b>D</b>	Alternate source of power	N/A	N/A	N/A
<b>E</b>	Hooters	N/A	N/A	N/A
<b>8</b>	<b>MOEFA:</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System:</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System:</b>			
<b>A</b>	Basement	N/A	N/A	N/A
<b>B</b>	Upper floor	N/A	N/A	N/A
<b>C</b>	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants:</b>			
<b>A</b>	Size of riser/down-comer	N/A	N/A	N/A
<b>B</b>	Number of hydrants per floor	N/A	N/A	N/A
<b>C</b>	Hose box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants:</b>			
<b>A</b>	Total number of hydrants	N/A	N/A	N/A
<b>B</b>	Hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping Arrangements:</b>			
<b>1</b>	<b>Ground level</b>			
<b>A</b>	Discharge of main pump	N/A	N/A	N/A
<b>B</b>	Head of main pump	N/A	N/A	N/A
<b>C</b>	Number of main pumps	N/A	N/A	N/A
<b>D</b>	Jockey pump out put	N/A	N/A	N/A
<b>E</b>	Jockey pump head	N/A	N/A	N/A
<b>F</b>	Standby pump out put	N/A	N/A	N/A
<b>G</b>	Standby pump head	N/A	N/A	N/A
<b>H</b>	Auto starting /manual stopping	N/A	N/A	N/A
<b>I</b>	Pump house access	N/A	N/A	N/A
<b>2</b>	<b>Terrace Level</b>			
<b>A</b>	Discharge of pump	N/A	220 LPM	MR
<b>B</b>	Head of the pump	N/A	40 m	MR
<b>C</b>	Power supply	N/A	Provided	MR
<b>D</b>	Auto starting of pump	N/A	Provided	MR

✓

<b>14 Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	N/A	5000 liters	MR
<b>15 Exit Signage:</b>		N/A	N/A	N/A
<b>16 Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17 Standby Power Supply:</b>		N/A	N/A	N/A
<b>18 Refuge Area:</b>				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19 Fire Control Room:</b>				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20 Special Fire Protection systems for protection of special Risks, if any:</b>		N/A	N/A	N/A


The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspection.


Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures required as per Circular No. 262-362 dated 17/01/2005, under the rules the FSC issued vide letter no. F6/MS/DFS/06/1745 dated 28/07/2006, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.


No file is pending with me before disposal of this case.


  
03/7/2024

Signature of the Inspecting Officer  
Name: - Yashwant Singh Meena  
Designation: - ADO (L.N)

~~DY.CFO (NDZ)~~   
04/07/24

~~C.F.O.~~   
5/7/2024

~~Director~~   
5/7/24

~~AO/LN~~ 

Sir. A.T Letter is put up for sign. Please

~~Director~~   
8/7/2024