



No. F6/DFS/MS/School/NDZ/2024/ 648

Dated: 09/07/2024

FIRE SAFETY CERTIFICATE

Certified that **K. S. Convent School** running on ground plus first floor only, located at **E – 88 A, Bhati Chowk, East Vinod Nagar, Delhi – 110091**, building comprised of ground plus two upper floor owned/ occupied by **K.S. Convent School**, was issued Fire Safety Certificate vide letter No **F6/MS/DFS/2006/1554** dated **12.07.2006**. The school building was re-inspected by the officer concerned of this department on 29/06/2024 in presence of Dr. Rajender Bhati (Manager) and observed that all the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 issued by Director of Education and that the building is fit for occupancy class **“Educational Building”** (Group - B) for **ground plus first floor only** with effect from 09/07/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 09/07/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi - 110053.
2. The Manager, K.S. Convent School located at E – 88 A, Bhati Chowk, East Vinod Nagar, Delhi – 110091.

Conditions for the validity of Fire Safety Certificate

1. **Fire Safety Certificate is valid for ground & first floor only.**
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/2
INSPECTION REPORT

1	Name & address of the building	K.S Convent School located at E - 88 A, Bhati Chowk, East Vinod Nagar, Delhi - 110091.
2	Building is comprised of	Ground plus two upper floor only (School running on ground plus one floor only) Second floor - Residence.
3	Type of occupancy	Educational Building
4	Type of case	Renewal
5	Details of previous FSC	F6/ MS/DFS/2006/1554 dated 12.07.2006
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005
7	Date of inspection	29/06/2024
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
9	Name of the designation of officer from the building side	Dr. Rajender Bhati (Manager)
10	Year of construction	2000
11	Applicant's letter no.	Email dated 24/06/2024

S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement As per D.O.E Circular dated 17.01.2005	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	6.0 mtrs. ✓	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	01 no.	02 nos.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs.	1.20 mtrs. & 0.50 mtrs ✓	MR (Old case)
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	01 no.	MR
E	Width of corridor	1.50 mtrs.	1.50 mtrs. ✓	MR
F	Door size	1.0 mtr.	1.0 mtr. ✓	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

(u)

5.	Fire Extinguisher:			
	A	Total numbers	06 nos.	15 nos. / MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC MR
	C	ISI marking	ISI Marked	Provided MR
6	First-Aid-Hose Reel:			
	A	Total numbers of each floor (G+1)	01 no.	01 no. / MR
	B	Length of hose reel hose	30 mtr.	30 mtr. MR
	C	Nozzle diameter	05 mm	05 mm MR
7	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	N/A	N/A N/A
	B	Location of main panel	N/A	N/A N/A
	C	Location of repeater panel	N/A	N/A N/A
	D	Alternate source of power	N/A	N/A N/A
	E	Hooters	N/A	N/A N/A
8	MOEFA:			N/A Provided / MR
9	Public Address System:			
10	Automatic Sprinkler System:			
	A	Basement	N/A	N/A N/A
	B	Upper floor	N/A	N/A N/A
	C	Sprinkler above false ceiling	N/A	N/A N/A
11	Internal Hydrants:			
	A	Size of riser/down-comer	N/A	N/A N/A
	B	Number of hydrants per floor	N/A	N/A N/A
	C	Hose box	N/A	N/A N/A
12	Yard Hydrants:			
	A	Total number of hydrants	N/A	N/A N/A
	B	Hose box	N/A	N/A N/A
13	Pumping Arrangements:			
1	Ground level			
	A	Discharge of main pump	N/A	N/A N/A
	B	Head of main pump	N/A	N/A N/A
	C	Number of main pumps	N/A	N/A N/A
	D	Jockey pump out put	N/A	N/A N/A
	E	Jockey pump head	N/A	N/A N/A
	F	Standby pump out put	N/A	N/A N/A
	G	Standby pump head	N/A	N/A N/A
	H	Auto starting /manual stopping	N/A	N/A N/A
	I	Pump house access	N/A	N/A N/A
2	Terrace Level			
	A	Discharge of pump	220 LPM	220 LPM / MR
	B	Head of the pump	40 m	40 m / MR
	C	Power supply	Required	Provided MR
	D	Auto starting of pump	N/A	N/A N/A

(u)


✓

14	Captive Water Storage for Fire Fighting:					
	A	Underground tank capacity	N/A	N/A	N/A	N/A
	B	Draw-off connection	N/A	N/A	N/A	N/A
	C	Fire service inlet	N/A	N/A	N/A	N/A
	D	Access to tank	N/A	N/A	N/A	N/A
	E	Overhead tank capacity	2500 liters. Required	2500 liters. Provided	MR	MR
15	Exit Signage:					
16	Provision of Lifts:					
	A	Pressurization of lift shaft	N/A	N/A	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A	N/A	N/A
	C	Communication in lift car	N/A	N/A	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A	N/A	N/A
	E	Lift signage	N/A	N/A	N/A	N/A
17	Standby Power Supply:					
18	Refuge Area:					
	A	Total area	N/A	N/A	N/A	N/A
	B	Location	N/A	N/A	N/A	N/A
19	Fire Control Room:					
	A	Detector system panel	N/A	N/A	N/A	N/A
	B	Flow switch panel	N/A	N/A	N/A	N/A
	C	PA system panel	N/A	N/A	N/A	N/A
	D	Battery backup	N/A	N/A	N/A	N/A
	E	Building floor plans	N/A	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:					

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.


Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/MS/DFS/2006/1554 dated 12.07.2006, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.


No file is pending with me before disposal of this case.



 02/7/2023


Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO (L.N)

~~DY. CFO/NDZ~~


 03/07/24

C.F.O.

 4/7/2024

Director

 5/7/24

Sir F.T Letter is put up for sign. Please
 Director

 8/7/24


 8/7/2024