

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6/DFS/MS/EH/2024/SZ/ 218

Dated..10../07/2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & Style of **M/s Mealszone Café Pvt. Ltd** Situated at **Ground Floor**, Qutab Hotel, Shaheed Jeet Singh Marg, New Delhi- 110016 in the building comprised of Basement Ground plus six upper floors owner/occupied by M/s Mealszone Café Pvt. Ltd was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/SZ/2021/166 Dated 30/07/2021. The premise was re-inspected by the officer concerned of this department on 27/06/2024 in the presence of Mr. Amit Kumar (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (Restaurant) and **Validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/07/2024 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police (Lic/Branch) 1st Floor, PS Defence Colony, New Delhi 110049. (Ref. MHA Portal ID 2024061709472 dated 17/06/2024)

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (l) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT



1	Name & Address of the Building	M/s Mealszone Café Pvt Ltd, at Block-A, Ground Floor, Qutab Hotel, Shaheed, Jeet Singh Marg, New Delhi - 110016		
2	Type of Occupancy	Group-D- Assembly (Restaurant)		
3	Building Comprised of	Basement, Ground + Six upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/SZ/2021/166 Dated 30/07/2021		
6	Fire Safety Directives Letter No	F6/DFS/MS/EH/2005/718 dated 04/04/2005		
7	Date of Inspection	27/06/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Amit Kumar (Manager)		
10	Year of construction	2002	Restt. running at ground floor of the building	
11	Applicant letter No.	MHA Portal ID 2024061709472 dated 17/06/2024		

S.No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Cir. Dt 04/04/2005 requirements	Provided at Site	Remarks MR/NMR
-------	---	---------------------------------------	------------------	-------------------

1	Access to Building.			MR
	Road width	Required	Provided	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	Required	Provided	MR

2	Number, width, type & arrangement of exits.			
	Number of Staircase			
	Upper floors.	N/A	N/A	N/A
	Basement floor.	N/A	N/A	N/A
	Width of Staircase			
	Upper floors	N/A	N/A	N/A
	Basement floor	N/A	N/A	N/A
	Protection of exits			
	Fire check door	N/A	N/A	N/A
	Pressurization	N/A	N/A	N/A
	No. of continuous staircase to terrace	N/A	N/A	N/A
	Width of corridor	N/A	N/A	N/A
	Door size	1.50 mtr each	2 m & 1.50 mtr	MR

3	Compartmentation.			
	Fire check door.	N/A	N/A	N/A
	Sealing of electrical shafts.	N/A	N/A	N/A
	Fire rating of shaft door.	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire dampers.	N/A	N/A	N/A

4	Smoke Management system.			
	Basement	12 ACPH	N/A	N/A
	Upper floors	12 ACPH	Exhaust fan Provided in restt.	MR

5	Fire Extinguishers.			
	Total numbers	10 Nos	10 Nos	MR
	Types	ABC/CO ₂	ABC & CO ₂	MR
	ISI Marking	ISI marked	Provided	MR

6	First Aid Hose Reels.			
	Total numbers on each floor.	One	Provided	MR
	Length of hose-reel hose.	30m	Provided	MR
	Nozzle Diameter	5mm	Provided	MR

7	Automatic fire detection & alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A

2

20/17

	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	Basement	N/A	N/A	N/A
	Ground floor & upper floor	Required	Provided	MR
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	Size of Riser/Down-comer	100 mm	Provided	MR
	Number of Hydrant per floor	One	Provided	MR
	Hose box.	One	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants.	N/A	N/A	N/A
	Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	Ground Level			
	Discharge of main pump.	N/A	N/A	N/A
	Head of main pump.	N/A	N/A	N/A
	Number of main pumps.	N/A	N/A	N/A
	Jockey Pump output.	N/A	N/A	N/A
	Jockey Pump head.	N/A	N/A	N/A
	Standby Pump output.	N/A	N/A	N/A
	Standby Pump head.	N/A	N/A	N/A
	Auto Starting/Manual Stopping.	N/A	N/A	N/A
	Pump house access.	N/A	N/A	N/A
	Terrace Level			
	Discharge of pump.	225 LPM	Provided	MR
	Head of pump.	40m	Provided	MR
	Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	Underground tank capacity.	N/A	N/A	N/A
	Draw-off connection.	N/A	N/A	N/A
	Fire Service Inlet.	Required	Provided	MR
	Access to tank.	N/A	N/A	N/A
	Overhead tank capacity.	2500 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of lift shaft.	N/A	N/A	N/A
	Pressurization of lift lobby.	N/A	N/A	N/A
	Communication in lift car.	N/A	N/A	N/A
	Fireman's switch.	N/A	N/A	N/A
	Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room.			
	Detector system panel.	N/A	N/A	N/A
	Flow switch panel.	N/A	N/A	N/A
	PA system panel.	N/A	N/A	N/A
	Battery backup.	N/A	N/A	N/A

5



N/18



	Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/SZ/2021/166 Dated 30/07/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

meel
Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Sh. Rajesh Kumar
Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ) *Hugh*
2/7/2024

Director
5/7/24

Ado/BCP

As approved, F.T. letter is put up for your signature pl

1/7/24

Director
9/7/24

U/boxed
10/7/24
D.