



No. F6/DFS/MS/CNG/NDZ/2024/ 443

Dated: 12/07/2024

FIRE SAFETY CERTIFICATE

Certified that the CNG Station located at CBD Shahdara, Delhi, Comprised of ground floor only, owned/occupied by Indraprastha Gas Limited was issued FSC vide letter no. F6/DFS/MS/CNG//2021/NDZ/388 dated 13/08/2021. The premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and re-inspected by the officer concerned of this department on 05/07/2021 in the presence of Mr. Vishwanath Mishra (G M Fire & Safety) and that the CNG station is fit for occupancy class "storage" (CNG Filling Station) with effect from 12/07/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions, printed overleaf.

Issued on 12/07/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE
@

Copy to: -

1. The Chief General Manager (Fire & Safety), IGL Bhawan, Plot No. 04, Community Center, R.K. Puram Sector - 09, New Delhi - 110022.

Conditions for the validity of Fire Safety Certificate

1. No trade susceptible to cause to CNG by generating head, mechanical/ electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipment, electrical gadgets and fitting in the premises shall conform to hazardous area classification for the at purpose and be of a type approved by the CCE.
3. In premises "NO Smoking" signs board both Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Noting contravention of the explosive Act. 1884 and rules their under 1983, and static mobile pressure vessels (Unfired) Rules 1981 as modified from time to time.
7. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. May be got verified from the concerned authorities..
8. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [Sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT


1	Name & address of the building	CNG Station at CBD Shahdara, Delhi		
2	Building is comprised of	Ground floor.		
3	Type of occupancy	CNG Storage & Dispensing Unit		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/CNG//2021/NDZ/388 dated 13/08/2021		
6	Fire safety directives letter no.	F.5(3A)/DFS/CNG/2000/312 dt-31/07/2000		
7	Date of inspection	05/07/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Vishwanath Mishra(G M Fire & Safety)		
10	Year of construction	2005		
11	Applicant's letter no.	Outdoor Diary No. 3542 dated-28/06/2024.		
S.N p	Minimum standard of fire prevention and fire safety U/R 33	As per Directives	Provided at site	Remarks MR/NMR
1	Access to Building:	12 meters.	30 meters. ✓	MR
	A Road width	N/A	N/A	N/A
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:	N/A	N/A	N/A
	A Number of staircases	N/A	N/A	N/A
	B Width of staircases	Required	Provided ✓	MR
3	Compartmentation:	Required	Provided ✓	MR
4	Smoke Management System:	Required	Provided ✓	MR
5	Fire Extinguisher:	25 nos.	25 nos. ✓	MR
	A DCP Type 10 kg	05 nos.	05 nos. ✓	MR
	B DCP Type 75 kg	06 nos.	06 nos.	MR
	C CO ₂ Type 4.50 kg	ISI Marked	ISI Marked	MR
	D ISI marking			
6	First-Aid-Hose Reel:	N/A	N/A	N/A
	A Total numbers of each floor	N/A	N/A	N/A
	B Length of hose reel hose	N/A	N/A	N/A
	C Nozzle diameter	N/A	N/A	N/A
7	Automatic Fire Detection and Alarming System:	Gas	Provided ✓	MR
	A Type of detectors	Required	Provided ✓	MR
	B Location of main panel	Required	Provided ✓	MR
	D Alternate source of power	Required	Provided	MR
	E Hooters	Required	Provided	MR
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	N/A	N/A
10	Automatic Sprinkler System:	N/A	N/A	N/A
11	Internal Hydrants:	N/A	N/A	N/A
12	Yard Hydrants:	N/A	N/A	N/A
13	Pumping Arrangements:			
	A Terrace Level	N/A	N/A	N/A
	B Discharge of pump	N/A	N/A	N/A
	C Head of the pump	N/A	N/A	N/A
	D Power supply	N/A	N/A	N/A
	E Auto starting of pump	N/A	N/A	N/A

14	Captive Water Storage for Fire Fighting			MR
15	Exit Signage/ No Smoking Signage	Required	Provided	MR
16	Provision of Lifts	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection systems			
	A CO2, DCP local application	Required	Provided	MR
	B Hand held explosive meter	02 nos.	Provided	MR



The fire protection system provided in the CNG station were tested / checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety Measures required under the rules, it is recommended to renew Fire Safety Certificate under rule 37 of delhi Fire Service Rules, 2010.

No file is pending with me before disposal of this case.



6/7/2024
Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (Laxmi Nagar)


~~DY. CFO/NDZ~~ 

~~C.F.O.~~ 
9/7/2024
~~Director~~ 
9/7/24

~~Anu LN~~

Six. F.T Letter is putup for sign. Please

~~Director~~ 
10/7/24
new


10/7/2024