



No. F6/DFS/MS/DMRC/NDZ/2024/ 445

Dated: 12/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s DMRC Dilshad Garden Metro Station located at Dilshad Garden, Delhi – 110095 comprised on ground, concourse level and platform level, owned/occupied by Delhi Metro Rail Corporation was issued Fire Safety Certificate vide letter No. F6/DFS/MS/DMRC/ 2021/351 dated 23/07/2021. The Metro Station building was re-inspected by the officer concerned of this department in the presence of Mr. Pankaj Kumar (Station Controller) & Mr. Kamal Deo (S.E). and found that the Metro Station building have deemed complied with the fire prevention and Fire Safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and observed that the building is fit for ground, concourse level and platform level occupancy class Group D “Assembly Building” with effect from 12/07/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions printed below.

Issued on 12/07/2024 at New Delhi by.

  
(ATUL GARG)  
DIRECTOR  
o/c DELHI FIRE SERVICE

**Copy to:-**

1. Sr. DGM/E & M, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/14

**INSPECTION REPORT**

1	Name & address of the building	Dilshad Garden Elevated Metro Station Line -01 located at Dilshad Garden, Delhi - 110095.		
3	Type of occupancy	Assembly Building (Ground, Concourse level and Platform level)		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/DMRC/2021/351 dated 23/07/2021.		
6	Fire safety directives letter no.	NBC Part - IV		
7	Date of inspection	05/07/2024.		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Pankaj Kumar (Station Controller) & Mr. Kamal Deo (S.E).		
10	Year of construction			
11	Applicant's letter no.	Outdoor dairy no. 3652 dated 01.07.2024		
S.No	<b>Minimum standard of fire prevention and fire safety U/R 33</b>	<b>NBC Part-IV Requirement</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building:</b>			
A	Road width	9.0 mtrs.	18 mtrs. ✓	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	04 nos.	02 +02 +04=08 nos. ✓	MR
c	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs	(6 mtr x2), 3.47 mtrs x2) & 1.20 mtrs x4 ) ✓	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	Required	Provided ✓	MR
b	Pressurization	Required	Provided ✓	MR
D	No. of continuous staircases to terrace	N/A	N/A	N/A
E	Width of corridor	N/A	N/A	N/A
F	Door size	2.0 mtrs	3.0 mtrs ✓	MR
3	<b>Compartmentation:</b>			
A	Fire check door	N/A	N/A	N/A
C	Sealing of electrical shafts	N/A	N/A	N/A
D	Fire rating of shaft door	N/A	N/A	N/A
E	Water curtain	N/A	N/A	N/A
F	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	Required	Ventilated	MR

(u)

<b>5.</b>	<b>Fire Extinguisher:</b>			
A	Total numbers	45 nos.	48 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>			
A	Total numbers of each Branch	04 nos	04 nos	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>			
A	Type of detectors	Smoke	Multi Sensor	MR
B	Location of main panel	Concourse	Provided	MR
C	Location of repeater panel	Main Entry	Provided	MR
D	Alternate source of power	Required	Provided	MR
E	Hooter's Location	Required	Provided	MR
<b>8</b>	<b>MOEFA:</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System:</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants:</b>			
A	Size of riser/down-comer	150 mm	150 mm	MR
B	Number of hydrants per Branch	04 nos.	04 nos.	MR
C	Hose box	04 nos.	04 nos.	MR
<b>12</b>	<b>Yard Hydrants:</b>			
A	Total number of hydrants	02 nos.	02 nos.	MR
B	Hose box	02 nos.	02 nos.	MR
<b>13</b>	<b>Pumping Arrangements:</b>			
<b>Ground level</b>				
A	Discharge of main pump	1800 LPM	1800 LPM	MR
B	Head of main pump	70 mtrs.	70 mtrs.	MR
C	Number of main pumps	01 no.	01 no.	MR
D	Jockey pump out put	225 LPM	225 LPM	MR
E	Jockey pump head	70 mtrs	70 mtrs	MR
F	Standby pump out put	1800 LPM	1800 LPM	MR
G	Standby pump head	70 mtrs.	70 mtrs.	MR
H	Auto starting /manual stopping	Required	Provided	MR
I	Pump house access	Required	Provided	MR
<b>Terrace Level</b>				
A	Discharge of pump	N/A	N/A	N/A
B	Head of the pump	N/A	N/A	N/A
C	Power supply	N/A	N/A	N/A
D	Auto starting of pump	N/A	N/A	N/A

(W)

✓

<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
	<b>A</b>	Underground tank capacity	50,000 liters.	2,00,000 liters ✓ MR
	<b>B</b>	Draw-off connection	Required	Provided MR
	<b>C</b>	Fire service inlet	Required	Provided MR
	<b>D</b>	Access to tank	Required	Provided MR
	<b>E</b>	Overhead tank capacity	N/A	N/A N/A
<b>15</b>	<b>Exit Signage:</b>		Required	Provided ✓ MR
<b>16</b>	<b>Provision of Lifts:</b>			
	<b>A</b>	Pressurization of lift shaft	N/A	N/A N/A
	<b>B</b>	Pressurization of lift lobby	N/A	N/A N/A
	<b>C</b>	Communication in lift car	Required	Provided ✓ MR
	<b>D</b>	Firemen's switch	Required	Provided ✓ MR
	<b>E</b>	Lift signage	Required	Provided ✓ MR
<b>17</b>	<b>Standby Power Supply:</b>		Required	Provided ✓ MR
<b>18</b>	<b>Refuge Area:</b>			
	<b>A</b>	Total area	N/A	N/A N/A
	<b>B</b>	Location	N/A	N/A N/A
<b>19</b>	<b>Fire Control Room:</b>			
	<b>A</b>	Detector system panel	Required	Provided ✓ MR
	<b>B</b>	Flow switch panel	Required	Provided ✓ MR
	<b>C</b>	PA system panel	Required	Provided ✓ MR
	<b>D</b>	Battery backup	Required	Provided ✓ MR
	<b>E</b>	Building floor plans	Required	Provided ✓ MR
<b>20</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>		N/A	N/A N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspections. The P.D. Area has already been cleared by Delhi Fire Service.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in under the rules the FSC issued vide letter no. F6/DFS/MS/DMRC/2021/351 dated 23/07/2021 is recommended to be renewed.

No File is pending with me before disposal of this case.

Signature of the Inspecting Officer  
 Name: - Yashwant Singh Meena  
 Designation: - ADO (L.N)

~~DY. CFO /NDZ~~

~~C.F.O.~~

~~Director~~  
 8/11/2024  
 ADO/LN

Sis. F.T Letter is put up for sign. Please

~~Director~~  
 10/11/2024

Signature  
 10/11/2024