



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/FW/2024/SZ/438

Dated: 10/07/2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Gian Chand Fireworks** located at Shop No. 1730/2 (Ground Floor), Gurudwara Road, Kotla Mubarak Pur, New Delhi-110003, comprised of ground plus two upper floors but the shop at ground floor only, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/FW/2018/SZ/2407 dated 26/10/2018. The said premise was re-inspected by the officer concerned of this department on 24/06/2024 in the presence of Sh. Anil Goel and observed that the said premises have deemed complied with the guidelines issued by Delhi Police under Delhi Police Act and that the said premises is fit for occupancy class "**Fireworks**" with effect from the date of issuance of this certificate for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/07/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/07

Copy to: -

1. The Addl. Commissioner of Police, Licensing Unit, First Floor, Police Station Defence Colony, New Delhi-10049
2. M/s Gian Chand Fireworks at Shop No. 1730/2 (Ground Floor), Gurudwara Road, Kotla Mubarak Pur, New Delhi-110003

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT				
1.	Name & address of the building	M/s Gian Chand Fireworks at Shop No. 1730/2, Gurudwara Road, Kotla Mubarakpur, New Delhi-110003		
2.	Type of Occupancy	Fireworks (Sale & Possession of Fireworks)		
3.	Building Comprised of	Ground + 02 upper floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/FW/2018/SZ/2407 Dt. 26/10/2018		
6.	Fire Safety directives letter No.	Nil		
7.	Date of inspection	24/06/2024		
8.	Name of Inspecting Officer	Santosh Kumar, ADO (SJ)		
9.	Name and designation of Officer from building side	Mr. Anil Goel		
10.	Year of Construction	N/A		
11.	Applicant letter No.	Outdoor Diary No. 2658 dated 07/06/2024		
S. No.	Points of Inspection	Requirement	Provided at site	Remarks MR/NMR
1.	Type of construction, floor area & floor level			
	a. Minimum floor area.	9m ²	16.44m ²	MR
	b. Construction	Pucca	Provided	MR
	c. Premises location	Not under staircase /means of escape	Complied	MR
	d. Business permissible only at ground level	Required	Provided	MR
	e. Business from pavement of road prohibited	Prohibited	Complied	MR
2.	Entrance & Exits to the Licensed Premises			
	The Licensed premises shall have independent entrance and exit.	Required	Provided	MR
3.	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15m from any premises used for similar explosive/inflammable or hazardous material.	Required 15m	Provided	MR
4.	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be for possession and sale of fireworks and no other purpose.	Required	Provided	MR
5.	Type of electrical wiring & electrical fitting			
	a. Preferably concealed or through conduit.	Required	Provided	MR
	b. All electrical fitting should be flame/ spark proof.	Required	Provided	MR
6.	Extension of shop for business			
	Prohibited	Prohibited	Complied	MR
7.	Approach Road			
	The road width on the side of which premises is located should be 12m	12m	Provided	MR
8.	Fire Protection Arrangement			
	a. Extinguisher Type & Nos.	2nos of Water type & 01no. of ABC/ CO ₂	Provided	MR
	b. Sand and Water buckets	2nos. each	Provided	MR
	c. Water Drum	01no.	Provided	MR
9.	Any other point that is contrary to the safety of people.			

Note: Presently the licensee/owner is running a shop in the said premises in the name of "Shri Balaji Bartan Bhandar" (Photograph enclosed), as the sale of fireworks is banned/stopped by the Govt. and submitted an affidavit that he will close the sale of Barnan as and when the sale of crackers is opened/allowed by the Govt. Further, as per Rule 87 of Explosive Rules, 2008, the premises may be used for other purpose, except for inflammable and dangerous substances when nitro-compound, fireworks are not stored in the premises.

Submitted for approved please.

The fire protection arrangements provided in the premises were checked, tested at random and found functional at the time.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/FW/2018/SZ/2407 dated 26/10/2028, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Santosh Kumar
 26/10/24
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

~~DO (SD)~~
MNV
 01/11/24

1. Is site inspection going on?
 2. Under which Rule? perhaps ^{possible} SC denied for the same. Clarify.

Vuf
 01/10/2024

 DO (SD)

MNV
 01/11/24

ADO (SJ) Sir,
 1) Site was inspected on receipt of letter from the office of joint Comm. of Police (lic.) ~~and through~~ ^{through proper} channel!
 2) No order is available in this office so far with regard discontinuation of inspection for firecrackers work.

N-24

Submitted for appropriate guidance /
order please.

Jyuman
04.07.24

~~DO/CSO~~

~~with
08/07/24~~

~~CSO
5 Aug
17/07/24~~

~~Director~~

~~9/07/24~~

AO/ST

Sr, FT letter is put up for your sig. pl

Jyuman
09.07.24

~~Director~~
~~9/07/24~~

RR
EV

No.
of
te
m
l.
De
vi
ru
f