

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6/DFS/MS/EH/2024/SZ/222

Dated..12/07/2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of **M/s Addonis** located at Whole CSC Complex, Hauz Khas, (SFS) New Delhi 110016 comprised of Ground & First Floor owned/occupied by A Unit of Blue Lightning Hospitality Pvt Ltd have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 27/06/2024 in the presence of Mr. Sumit Kumar and that the premise is fit for occupancy class **Group-D Assembly Building** (Restaurant) and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/07/2024 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police Lic Branch, 1st Floor, PS Defence Colony, New Delhi 110049 (Ref MHA Portal ID 2024060608913 dated 14/06/2024)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	M/s Addonis (Unit of Blue Lightning Hospitality Pvt Ltd) located at Whole CSC Complex, Hauz Khas, New Delhi 110016.		
2	Type of Occupancy	Assembly Building "Group-D"		
3	Building Comprised of	Ground & Floor floors		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	27/06/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Sumit Kumar		
10	Year of construction	1983		
11	Applicant letter No.	MHA Portal ID 2024060608913 dated 14/06/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL 2016	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	09 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	• Upper floors	02 Nos	02 Nos	MR
	• Basement floor	NA	N/A	N/A
	b. Width of Staircase			
	• Upper floors	1.50 mtr each	2 x 1.50 mtr	MR
	• Basement floor	NA	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.50mtr each	1.50 mtr each	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	12 ACPH	Provided	MR
5	Fire Extinguishers.			
	• Total numbers	Required	06 Nos.	MR
	• Types	ABC/CO2	ABC/Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	01 No each	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic Fire Detection and Alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A

N/A
N/A
2

Special Fire Protection System for the Protection of special Risk, if any :	N/A	N/A	N/A
---	-----	-----	-----

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

[Handwritten Signature]

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

[Handwritten Signature]
9/2/24

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)
|
|

[Handwritten Signature]
4/7/2024

~~Director~~ *[Handwritten Signature]*
5/7/24

[Handwritten Signature]

As approved, f-t. letter is forward for your signature pl

[Handwritten Signature]
9/2/24

~~Director~~ *[Handwritten Signature]*
12/07/24

[Handwritten Signature]

Uploaded
13/7/24

[Handwritten Signature]