

c 24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**  
No.F6/DFS/MS/2024/ School/ 676 Dated: 16/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Baba Sahib Ambedkar Secondary School Rani Jansi Road Pahar Ganj New Delhi-55**, comprises of **Ground + 03 upper floor** but school is **running at ground and first floor only**. The premises was inspected by the officer concerned of this department on 05.07.24 in the presence of Mr. Raj Bir Singh Bhandari, Vice Principal and found that school has deemed complied with the fire prevention and fire safety requirements in accordance with **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. B-I ground & Ist floor school** with effect from ~~-----16/07-----~~ 16/07/2024 for a period of three years subject to compliance of the conditions mentioned below:

Issued on .....16/07/2024..... at New Delhi by.

Yours faithfully

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. Director of Education, Old Secretariat, New Delhi.
2. The Principal Baba Sahib Ambedkar Secondary School Rani Jansi Road Pahar Ganj New Delhi-55.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
2. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. The compliance with regards to electrical installation, structural stability, set back area occupancy and any deviation in construction etc. shall be verified from authority concerned
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. Any flammable material for interior decoration shall strictly prohibited.

N/18  
**INSPECTION REPORT**

- |  |   |
|--|---|
| 1. Name & address of the building                            | <b>Baba Sahib Ambedkar Secondary School<br/>Rani Jansi Road Pahar Ganj New Delhi-55</b>                       |
| 2. Type of occupancy:-                                       | <b>Educational Group-B<br/>Gr. + 03 Upper floor, but school is running<br/>at Ground and first floor only</b> |
| 3. Type of case:-  | <b>New / existing</b>   |
| 4. Details of previous FSC:-                                 | <b>N/A</b>  |
| 5. Fire safety directives No.-                               | <b>N/A</b>  |
| 6. Date of inspection:-                                      | <b>05/07/24</b>   |
| 7. Name of the inspecting officer:-                          | <b>Sh. Ravinder Singh (ADO/CC)</b>  |
| 8. Name & designation of officer<br>From the building side:- | <b>Sh. Rajbeer Singh Bhandari<br/>old building</b>  |
| 9. Year of construction:-                                    | <b>No. BSA/SS/2024/1800 dated 25/06/2024</b>  |
| 10. Applicant's letter No:-                                  | <b>New case</b>   |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per circular of Dir. of Edu. Dt 17.01.2005	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	09mtr.	MR
	2) Gate width	4.5mtr	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.10 & 1.20 mtr	1.10 & 1.20 mtr . ✓	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	08 Nos	MR
	2) Types	ABC & CO2	ABC, CO2 & w.CO2	MR
	3) ISI marking	N/A	N/A	N/A

*Handwritten signature*

N/A

6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	100 mm	N/A
	2) Number of hydrants per floor	N/A	01 nos	N/A
	3) Hose box	N/A	Provided	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	220 LPM	Provided	MR
	b) Head of pump	40 mtr	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank	2500 ltrs.	Provided	MR

l c.

✓

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any.			MR

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may issue the FSC to said school premises up to first floor. Accordingly, DFA is prepared and put up for kind perusal and sig. please.

Signature of the Inspecting Officer



Name :- Ravinder Singh  
Designation :- ADO (CC)

~~D. S. Singh~~

~~D. S. Singh~~  
8/7/24

~~Dy. CCS (C-2)~~

~~ADP~~  
09/07/24

~~C.F.O.~~  
~~Director~~  
10/07/24  
12/07/24

Page 4

DD