

C-85

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2024/GH/286

Dated: 12/07/2024

FIRE SAFETY CERTIFICATE

Certified that the building of M/s Hotel Sun Star Heritage, Located at Ground, 1st, 2nd & 3rd floor 8A/43, WEA, Karol Bagh, New Delhi-110005, in a building comprised of basement, ground plus three upper floors using basement as (storage), ground floor (reception & 03 guest room), first, second & third floor (5 rooms each floor) (Total=18 guest rooms) and 01 staff room with pantry on terrace (now sealed/closed) was issued FSC vide Letter No F6/DFS/MS/GH/SZ/2021/156, dated 25/03/2021. The premises was re inspected by the officer concerned of this department on 08/07/2024 in the presence of Sh. Abhinav Sharma and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" (guest house) at **ground floor (reception & 03 guest room), first, second & third floor (5 rooms each floor) (Total=18 guest rooms)** with effect from 12/07/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...12/07/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
o/c

Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Manager, M/s Hotel Sun Star Heritage, Located at Ground, 1st, 2nd & 3rd floor 8A/43, WEA, Karol Bagh, New Delhi-110005.

Following fire safety directives must be adhered to:-

1. 4th floor shall not be used for any purpose as undertaking given by owner.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement strictly shall be kept vacant as seen during inspection.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M/s Hotel Sun Star Heritage, Located at Ground, 1st, 2nd & 3rd floor 8A/43, WEA, Karol Bagh, New Delhi-110005.
2. Type of Occupancy : Lodging or rooming "A-1"
3. Type of Case : Renewal (Running at Ground, 1st, 2nd & 3rd floor in a building comprised of Basement + Ground + 03 Upper Floors and 01 staff room with pantry on terrace (now sealed/closed)
4. Details of previous NOC : F6/DFS/MS/GH/SZ/2021/156, dated 25/03/2021
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 08/07/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Abhinav Sharma
9. Year of Construction : Before 2001
10. Applicant's letter No. : 2024042005636, dated 19/06/2024


S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/30, N/31 & N/32	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	-----	Direct accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 No.	01	MR (Being old case)
	• Basements	01 No.	01 Nos.	MR
	b. Width of staircases			
	• Upper floors	Old case	1.22 m	MR (Being old case)
	• Basements	Old case	1.15m	MR (Being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	1 m	1.20m	MR (Being old case)
	f. Door Size	Old case	0.75m	MR (Being old case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR


5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	15 Nos. ABC & CO ₂ Required	Provided CO ₂ & ABC Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 mtr 5 MM	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	CO detectors NA NA Required NA	Provided NA NA DG set 82 KVA NA	MR NA NA MR NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	Provided NA NA	Area less than 200 sq.mtr NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 mtrs Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR


[Handwritten signature]

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	---
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	Old case	5,000 ltr	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA


The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/GH/SZ/2021/156, dated 25/03/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved the FSC may be issued.


 Signature of the Inspecting Officer
 Name: Sh. Udaivir Singh
 Designation : ADO (DWK)


 9/12/24


 Cfo (S2)
 9/12/2024


 ADO/ADL
 12/12/24


 Uplanded
 13/12/24
 MS recd