



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTER: DELHI FIRE SERVICE: NEW DELHI- 110001

C-47

7-  
आजादी अमृत महोत्सव

No. F6/DFS/MS/WZ/School/2024/WZ/ 678

Dated:- 16/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Modern Child Public School Located at Punjabi Basti, Nangloi, Delhi-110041, comprised of Basement + Ground + 02 Upper Floors only owned/occupied by the Modern Child Public School, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/WZ/1284 dated 28/08/2017. The said premise was re-inspected by the officer concerned of this department on 08/07/2024 in the presence of Dr. Vivek Yadav (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17/01/2005/NBC (Part-IV) and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 16/07/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 16/07/2024 at New Delhi by

(Atul Gang)  
Director

Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Modern Child Public School, Punjabi Basti, Nangloi, Delhi-110041.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name and address of the building: **Modern Child Public School, located at Punjabi Basti, Nangloi, Delhi-110041**
2. Type of Occupancy : Educational (Basement + G + 02 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/WZ/1284 Dated 28/08/2017
5. Fire Safety directives Letter No. : DOE. Cir. 262-362 dated 17/01/2005/NBC (Part-IV)
6. Date of inspection : 08/07/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Dr. Vivek Yadav (Manager)
9. Year of Construction : 1995
10. Applicant's letter No. : email dated 27/06/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 262-362 dated 17/01/2005/as per FSC dated 28/08/2017	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 m	1.50 m x 1 1.65 m x 1	MR
	• Basements	1.5 m	2.40 m x 2	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1.0 m (class room) 1.5 m (Hall)	1.0 (class room) 2.40 m x 2 (Hall)	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Natural Ventilation	MR

5.	Fire Extinguishers	10 nos.	21 nos.	MR
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	ABC & CO <sub>2</sub>	Provided	MR
		ISI Marked	Provided	MR
6.	First – Aid Hose Reel	01	Provided	MR
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	30 m	Provided	MR
		05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm	Provided	MR
		01 each floor	Provided	MR
		01 each floor	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		180 lpm	Provided	MR
		40 m	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
		10,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA

18.	Refuge Area			
	> Total area	NA	NA	NA
	> Location	NA	NA	NA
19.	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- There is a Multipurpose Hall in basement equipped with sprinklers, fire extinguishers etc. having sufficient exits (Two Doors of 2.40 m each).

Fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings issued vide letter no. F6/DFS/MS/School/WZ/2021/528 dated 01/10/2021 found rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 262-362 dated 17/05/2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2017/WZ/1284 Dated 28/08/2017 is recommended.

Accordingly DFA is prepared for approval & signature please.

~~DCFB (202)~~

*Qmita d*  
09/07/24  
Aman Kumar Lathar  
ADO (JWP)

FOI-312  
Dated-11/7/24

~~S/o~~  
11/7/2024

~~Director~~  
13/07/24  
AOD/JWP

Sir, FF. letter is added for your signature (A).

~~Director~~  
13/07/24

*Qmita d*  
15/7/24  
AOD (JWP)