



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/2024/School/658

Dated: 10/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **Nalanda Modern Public School** located at **Sant Nagar, Main Road Burari, Delhi-110084** comprised of **02 blocks, A-block comprised of Basement+Ground+03 upper floors & B-Block comprised of Ground +03 upper floors** owned/ occupied by **Nalanda Modern Public School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/School/2021/843** dated **12.10.2021**. The premise was re-inspected by the officer concerned of this department on **04.07.2024** in the presence of **Sh. Devi Prasad Vats (Chairmen)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from**10/07/2024** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on ...**10/07/2024**.... at New Delhi


(Atul Garg)
Director
Ph.-011-25104544

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Director, Nalanda Modern Public School at Sant Nagar, Main Road Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Nalanda Modern Public School at Sant Nagar, Main Road Burari, Burari, Delhi-110084.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 02 blocks, 01 block comprised of B+G + 03 upper floors but School is running on Ground + 03 upper floors & 01 block comprised of ground + 03 upper floors only
5. Details of previous NOC : F6/DFS/MS/School/2021/843 Dated: 12.10.2021
6. Fire Safety directives letter No : NBC Part 4.
7. Date of inspection : 04.07.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. Devi Prasad Vats (Chairmen)
10. Year of Construction : 1995
11. Applicant's letter No. : Online E-mail Dated: 27.06.2024

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements/ Inspection dated 22.05.2014	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR(being Old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Block-A-02 Block-B-02	Block-A-03 Block-B-02	MR
	• Basements	02	basement of 100 yards, Block-A	MR
	b. Width of staircases			
	• Upper Floors	1.50 m	Block-A-1.27m, 1.28m & 1.50m Block-B-1.50m each	MR (being old case)
	• Basements	Block-A	02 separate basement in basement floor of 100 yards	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
e. Width of Corridor	NA	NA	NA	
f. Door Size	1m	1m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA

	• Upper floors	N/54 Required	Natural Ventilation	
5	Fire Extinguishers			
	• Total numbers	32nos	32nos	MR
	• Types	ABC/Co2	Provided	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	Block-A- 02nos. Block-B - 01nos.	Provided	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5m	5m	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	Block-A Block-B	Provided	MR
	• Hose Box	Block-A Block-B	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450lpm each block	Provided	MR
	➤ Head of the pump	40m	Provided	MR
		Required	Provided	MR

		Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	A-Block-10,000 LTR B-Block- 5000 LTR.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/School/320 dated 12.06.2024.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by NBC Part-IV, the FSC issued vide letter of even no.F6/DFS/MS/School/2021/843 dated 12.10.2021 renewal under rule 37 of the Delhi Fire Service Rules, 2010

10201-02
Dated: 05/07/2024

DO(NW)
05/07/2024
By: [Signature]
[Signature] (102)

[Signature]
Signature of the Inspecting Officer
Name:-C.L. Meena
Designation:- Asst. Div. Officer (RN)

[Signatures]