



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTER: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2024/ 675

Dated:- 15/07/2024

FIRE SAFETY CERTIFICATE

Certified that the Vishal International School, Located at F-45, Gali No. 15, Kunwar Singh Nagar, Nangloi, Delhi-110041, comprised of Ground Floor only owned/occupied by the Vishal International School have complied with the fire prevention and fire safety requirements in accordance with D.O.E Circular No. 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 04/07/2024 in the presence of Sh. Vikas Garg (Manager) and that the building/premises is fit for occupancy class "Educational Building" Group B with effect from 15/07/2024 for a period of three years, subject to compliance of the conditions, printed below

Issued on...at New Delhi by.

15/07/2024

(Atul Garg)
Director

Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi-110054
2. The Principal, Vishal International School, F-45, Gali No. 15, Kunwar Singh Nagar, Nangloi, Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **Vishal International School** located at **F-45, Gali No. 15, Kunwar Singh Nagar, Nangloi, Delhi-110041**
2. Type of Occupancy : Educational (Ground Floor only)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 04/07/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Vikas Garg (Manager)
9. Year of Construction : 2024
10. Applicant's letter No. : email dated 25/06/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | D.O.E. Cr. No. 3298-3398 dated 01.03.2011/ Requirements | Provided at site | Remarks MR/NMR |
|------|---|---|------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 06 m | Provided | MR |
| | • Gate width | 4.5 m | Provided | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 1.0 m | Provided | MR |
| 3. | Compartmentation | | NA | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 02 nos. | Provided | MR |
| | • Types | ABC & CO ₂ | Provided | MR |
| | • ISI marking | ISI Marked | Provided | MR |

| | | | | |
|-----|--|----|----|----|
| 6. | First-Aid Hose Reel | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | • Size of riser/down- comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements: | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power supply | NA | NA | NA |
| | ➤ Auto starting of pump | NA | NA | NA |
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage | NA | NA | NA |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |

| | | | | |
|-----------------------|--|----|----|----|
| 19. Fire control room | | | | |
| ➤ | Detector system panel | NA | NA | NA |
| | Flow Switch Panel | NA | NA | NA |
| | PA System Panel | NA | NA | NA |
| | Battery backup | NA | NA | NA |
| | Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view substantial compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Cr. No. 3298-3398 dated 01.03.2011, grant of Fire safety Certificate is recommended under rule 35 of the Delhi Fire service Rules 2010 under the DFS Act 2007.

Accordingly DFA is prepared for approval & signature please.

Director

15/07/24

CFO

15/07/2024

Director

15/07/24

15/07/24

Sd/-

F.F. letter is added for your signature pl!

Director
15/07/24

15/07/24
ADO (JWP)

15/07/24

Aman Kumar Lathar
ADO (JWP)

DFA No. 310
Dated: 15/07/24