



**FIRE SAFETY CERTIFICATE**

Certified that the **Building No. 06, New Rajdhani Enclave, Delhi - 110092**, comprised of basement (Store), ground plus three upper floors only, owned/occupied by **Vidyapeeth (Physics wala)** have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 02/07/2024 in the presence of Mr. Paramjeet Singh Yadav (Owner) & Mr. Anupama (Manager) and that the building /premises is fit for occupancy class "**Educational Building**" (Group - B) with effect from 18/07/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued 18/07/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE  
@

Copy to: -

1. Mr. Paramjeet Singh Yadav, Building No. 06, New Rajdhani Enclave, Delhi - 110092.

**Condition for the validity of fire safety certificate**

1. **Fire Safety Certificate is valid for ground plus three upper floors only.**
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. Basement shall be used strictly as per Building By-Laws 1983.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

219  
**INSPECTION REPORT**

1	Name & address of the building	Building No. 06, New Rajdhani Enclave, Delhi - 110092.
2	Building is comprised of	Basement (Store) + Ground + 03 upper floors only.
3	Type of occupancy	Educational Building (Coaching Classes)
4	Type of case	New Case
5	Details of previous FSC	Nil
6	Fire safety directives letter no.	NBC Part - IV
7	Date of inspection	02.07.2024
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
9	Name of the designation of officer from the building side	Mr. Parmjeet Singh Yadav (Owner) & Mr. Anupama (Manager)
10	Year of construction	2015
11	Applicant's letter no.	Outdoor Diary No. 3381 dated 25.06.2024

S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part - IV Requirement	Provided at site	Remarks MR/NMR
------	--	---------------------------	------------------	----------------

1	<b>Access to Building:</b>				
	A	Road width	6.0 meters.	On Main Road	MR
	B	Gate width	N/A	N/A	N/A
	C	Width of internal road	N/A	N/A	N/A

**2 Number, Width, Type and Arrangement of Exits:**

A	Number of staircases				
	a	Upper floor	02 nos.	03 nos.	MR
	b	Basement	02 nos.	02 nos.	MR
B	Width of staircases				
	a	Upper floor	1.50 mtrs.	1.50 mtrs. X 02 nos. & 1.20 mtrs.	MR
	b	Basement	1.50 mtrs	2.40 mtrs. & 1.20 mtrs.	MR
C	Protection of exits				
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace		01 no.	01 nos.	MR
E	Width of corridor		1.50 mtrs	1.50 mtrs ✓	MR ✓
F	Door size		1.50 mtrs	1.50 mtrs. x 02 ✓	MR ✓

**3 Compartmentation:**

A	Fire check door	N/A	N/A	N/A
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A

**4 Smoke Management System:**

A	Basement	Required	Provided (Exhaust Fan)	MR
B	Upper floor	Required	Natural Ventilation	MR

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	08 nos.	10 nos.	MR
	<b>B</b>	Types	ABC& CO <sub>2</sub>	ABC& CO <sub>2</sub>	MR
	<b>C</b>	ISI marking	ISI Marked	ISI Marked	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>				
	<b>A</b>	Total numbers each floor	01 no.	01 no.	MR
	<b>B</b>	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	<b>C</b>	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	N/A	N/A	N/A
	<b>B</b>	Location of main panel	N/A	N/A	N/A
	<b>C</b>	Location of repeater panel	N/A	N/A	N/A
	<b>D</b>	Alternate source of power	N/A	N/A	N/A
	<b>E</b>	Hooters	N/A	Provided	N/A
<b>8</b>	<b>MOEFA:</b>		Required	Provided	MR
<b>9</b>	<b>Public Address System:</b>		N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	N/A	N/A	N/A
	<b>B</b>	Upper floor	N/A	N/A	N/A
	<b>C</b>	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	100 mm	100 mm	MR
	<b>B</b>	Number of hydrants per floor	01 no.	01 no.	MR
	<b>C</b>	Hose box	01 no.	01 no.	MR
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	N/A	N/A	N/A
	<b>B</b>	Hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping Arrangements:</b>				
<b>1</b>	<b>Ground level</b>				
	<b>A</b>	Discharge of main pump	N/A	N/A	N/A
	<b>B</b>	Head of main pump	N/A	N/A	N/A
	<b>C</b>	Number of main pumps	N/A	N/A	N/A
	<b>D</b>	Jockey pump out put	N/A	N/A	N/A
	<b>E</b>	Jockey pump head	N/A	N/A	N/A
	<b>F</b>	Standby pump out put	N/A	N/A	N/A
	<b>G</b>	Standby pump head	N/A	N/A	N/A
	<b>H</b>	Auto starting /manual stopping	N/A	N/A	N/A
	<b>I</b>	Pump house access	N/A	N/A	N/A
<b>2</b>	<b>Terrace Level</b>				
	<b>A</b>	Discharge of pump	900 LPM	900 LPM	MR
	<b>B</b>	Head of the pump	40 M	40 M	MR
	<b>C</b>	Power supply	Required	Provided	MR
	<b>D</b>	Auto starting of pump	Required	Provided	MR

<b>14 Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	Required	Provided ✓	MR
D	Access to tank	Required	Provided ✓	MR
E	Overhead tank capacity	15,000 liters	15,000 liters ✓	MR
<b>15 Exit Signage:</b>		Required	Provided	MR
<b>16 Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17 Standby Power Supply:</b>		Required	Provided	MR
<b>18 Refuge Area:</b>				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19 Fire Control Room:</b>				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20 Special Fire Protection systems for protection of special Risks, if any:</b>		N/A	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/C.C/NDZ/2024/139 dated 05.06.2024 by this department have been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010.



8/7/2024  
 Signature of the Inspecting Officer  
 Name: Yashwant Singh Meena  
 Designation: ADO (L.N)

~~DY.CEO/NDZ~~  
 C.F.O.  
 Director  
 12/7/2024  
 09/07/24  
 15/07/24

Auth  
 P.T.O