



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2024/EH/ 226

Dated 16 /07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Govardhan Motels & Restaurant located at Ground Floor, Property No-28/5, Shakti Nagar, Delhi-110007 in the building comprised of ground & first floors only owned/ occupied by M/s Govardhan Motels & Restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 01.07.2024 in the presence of Sh. Varun Gupta and that the building/ premise is fit for occupancy "Group D Assembly (Restaurant)" for ground floor only with effect from 16/07/2024 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/07/2024 at New Delhi by

(Atul Garg)  
 Director  
 PH-011-23414000

Copy to:-

1. M/s Govardhan Motels & Restaurant located at Ground Floor, Property No-28/5, Shakti Nagar, Delhi-110007.

**Conditions for the validity of Fire Safety Certificate:**

1. This Fire Safety Certificate is valid only for restaurant at ground floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
4. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of firefighting system.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms).
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : M/s Govardhan Motels & Restaurant located at GF, Property No-28/5, Shakti Nagar, Delhi-110007.
2. Type of Occupancy : Assembly (Restaurant)
3. Composition of building : Ground & first floors, But restaurant running is ground floor only, 1<sup>st</sup> floor use for residence purpose.
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : NBC Part IV
7. Date of inspection : 01.07.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Varun Gupta
10. Year of Construction : 2000 As per MHA Portal
11. Applicant's letter No. : Online MHA Portal ID No-2024051307469 dated: 19.06.2024

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>	06m	08m approx..	MR
	• Road width	NA	NA	NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	02nos of 1.50m	2.30m & 1.50m	MR
	f. Door Size			
3	<b>Compartmentation.</b>	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>	NA	NA	NA
	• Basements	Required	Provided	MR
	• Upper floors (Ground floor)			
5	<b>Fire Extinguishers</b>	04nos	04nos,	MR
	• Total numbers	ABC & Co2	ABC - 04	MR
	• Types	Yes	Yes	MR
	• ISI marking			
6	<b>First-Aid Hose Reels.</b>			

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01	01	
		30m	30m	MR
		5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100mm	Provided	MR
		01	01	MR
		01	01	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive Water Storage for firefighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		20,000 LTR	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			

MR  
MR  
1R

14/7


	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA


Note:-

- (a) The total covered area of the ground floor is 143.5sqm (Approx) including seating area, toilet area.
- (b) As per the NBC Part IV, the number of occupants comes out to be approx 80 person's i.e.  $(143.5/1.8=80)$ .


The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/2024/EH/233 dated: 06.06.2024 have been compiled by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

  
Signature of the Inspecting Officer  
Name :- C.L. Meena  
Designation:- ADO/RN

DO (NW)  
  
04/07/2024

By CFO (W2)

  
5/7/2024

CFO

Please speak things  
8/7/2024

DD + DyCFO (W2)

CFO-326  
5/7/2024

P.T-0.