

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/2024/SZ/ 461

Dated: 23/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Aakash Healthcare Super Specialty Hospital Pvt. Ltd. Located at Sector-3 Dwarka, New Delhi comprised of three tier basement, Ground + Service Floor + 7 Upper Floor owned/occupied by M/s Aakash Healthcare Pvt. Ltd. was issued FSC vide Letter No. F6/DFS/MS/Hospital/SZ/2021/514, dated- 21/10/2021. The premises was re inspected by the officers concerned of this department on 02/07/2024 in the presence of Sh. Manoj Sant (Administration Head) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Institutional" Hospital with effect from 23/07/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/07/2024 at New Delhi by.

o/c  
Atul Garg  
(Director)  
Delhi Fire Service

Copy to: -



1. The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.
2. The Director, General of Health Service, F-17, Karkardooma Delhi-110032
3. Aakash Healthcare Super Specialty Hospital Pvt. Ltd. Located at Sector-3 Dwarka, New Delhi.

**Following fire safety directives must be adhered to:-**

1. **This FSC is for only old building, not valid for addition/alteration part as work is under progress.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.

11/5  
**INSPECTION REPORT**

1. Name & address of the building: Aakash Healthcare Super Speciality Hospital Pvt. Ltd. Located at Sector-3 Dwarka, New Delhi
2. Type of Occupancy : Institutional(Hospital) comprised of three tier basement, Ground + Service Floor + 7 Upper Floors
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Hospital/SZ/2021/514, dated- 21/10/2021
5. Fire Safety directives L. No: F6/DFS/MS/BP/Hospital/2017/279 Dated 19/09/2017.
6. Date of inspection : 02/07/2024
7. Name of the Inspecting Officer : DO/SW & ADO DWK
8. Name and designation of Officer :  
from the building side : Sh. Manoj Sant (Administration Head)
9. Year of Construction :2017
10. Applicant's letter No. : Nil dated - 12/06/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/41, N/42, N/43 & N/44	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	12 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	6 m	clear 	MR 
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	a. Number of staircases			
	• Upper floors	05	Provided	MR
	• Basements	06 + 01 Ramp	Provided	MR
	b. Width of staircases			
	• Upper floors	2mtr each	Provided (Old case)	MR(Being Old Case)
	• Basements	2mtr each & Ramp	2mtr each + Ramp	MR(Being Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	06 Nos.	Provided	MR
	e. Width Of Corridor	2.40m	Provided( Old case)	MR(Being Old Case)
	f. Door Size	Patient rooms 1.25,1.50&2 m	Provided( Old case)	MR(Being Old Case)
3.	<b>Compartmentation</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	2 hours rating	Provided	MR
	• Water Curtain	Required in basement	Provided	MR
	• Fire Dampers	Required	Provided	MR





4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30a/c per hour 12a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	As per IS ABC & CO2, ISI marked	52 Nos. Provided Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	02 Nos. 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke & Heat Basement floor-1 Required Required Appropriate places	Provided Provided All Levels Provided Near stairs at each floor	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required Required Required	Provided Provided Provided	MR MR MR
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150mm 02 No. 02 No.	Provided 02 No. 02 No.	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	06 Nos. 06 Nos.	06 Nos. 06 Nos.	MR MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	2850 lpm 70 m 2 Nos. 180 lpm(2No.) 70m Curtain pump 900 lpm 70m Required Required NA NA NA NA	Provided Provided Provided Provided Provided Provided 70m Provided Provided Provided NA NA NA NA	MR MR MR MR MR MR MR MR MR MR NA NA NA NA

N/A

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	2,00,000 litre	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000ltr	20,000ltr	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG set 500KVA	MR
18.	Refuge Area			
	➤ Total area	Required	105 m <sup>2</sup> approx	MR
	➤ Location	5 <sup>th</sup> Floor	Provided	MR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 flooding system in HT & LT.Panels.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/2020/Hospital/509 dated 07/12/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*The new part of the hospital is under construction and this renewal of FSC is only for old portion.*

*Sh. Vedpal*

Sign of Inspecting Officer  
Name: Sh. Vedpal  
Designation : DO/SW

*Udai vir Singh*

Sign of Inspecting Officer  
Name: Udai vir Singh  
Designation: ADO/DWK.

*CFO(S2)*

*15/11/2021*  
*Director*  
*12/01/22*

*Ado/DWK*