



No. F6/DFS/MS/DMRC/NDZ/2024/ 463

Dated: 23/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **Mayur Vihar Ph-1, Elevated Metro Station, building of Line-7, Delhi** – building comprised of **ground level, mezzanine level, concourse level and platform level**, owned/occupied by **Delhi Metro Rail Corporation** was issued Fire Safety Certificate vide letter No. **F6/DFS/MS/DMRC/NDZ/2021/452 dated 17/09/2021**. The Metro Station building was re-inspected by the officer concerned of this department on 15/07/2024 in the presence of Mr. Sanyam Jain (AM/Fire), and found that the Metro Station building have deemed complied with the fire prevention and Fire Safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group D-7 “Assembly Building”** with effect from **23/07/2024** for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions printed below.

Issued on 23/07/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE

Copy to:-

1. Mr. Vivek Shrivastava, JGM/E&M-II, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Mayur Vihar Ph-1, Elevated Metro Station, building of Line -07 , Delhi-			
3	Type of occupancy	Assembly Building "Group D-7" (Ground level, Mezzanine level, Concourse level and Platform level)			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/DMRC/NDZ/2021/452 dated 17/09/2021.			
6	Fire safety directives letter no.	F6/DFS/MS/BP/2013/163 dated 02/07/2013			
7	Date of inspection	15/07/2024.			
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)			
9	Name of the designation of officer from the building side	Mr. Sanyam Jain (AM/Fire)			
10	Year of construction	2018			
11	Applicant's letter no.	Outdoor dairy no. 3880 dated 08.07.2024			
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR	
1	Access to Building:				
	A	Road width	6.0 mtrs.	21 mtrs. vide main road ✓ MR	
	B	Gate width	N/A	N/A N/A	
	C	Width of internal road	N/A	N/A N/A	
2	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
		a	Upper floor	08 nos.	08 nos ✓ MR
		c	Basement	N/A	N/A N/A
	B	Width of staircases			
		a	Upper floor	08 nos	G+M(4.60 m-01), +1 ESC(existing metro)+M(2.50m-01)+2 ESC, M+C(3.25m-01)+2 ESC, C+P(2.75m-04)+4ESC, G+C(2.70m-01)+2ESC (50% cap. of Escalators is counted for evacuation in NFPA) MR
		b	Basement	N/A	N/A N/A
	C	Protection of exits			
		a	Fire check door	Required	Provided ✓ MR
		b	Pressurization	N/A	N/A N/A
		D No. of continuous staircases to terrace			N/A N/A N/A
		E	Width of corridor	1.50 mtrs	1.50 mtrs ✓ MR
		F	Door size	2.0 mtrs	2.0 mtrs & 1.50 mtrs ✓ MR
	3	Compartmentation:			
A		Fire check door	Required	Provided ✓ MR	
C		Sealing of electrical shafts	Required	Provided ✓ MR	
D		Fire rating of shaft door	2 hrs	2 hrs MR	
E		Water curtain	N/A	N/A N/A	
F		Fire dampers	N/A	N/A N/A	
Smoke Management System:					
4	A	Basement	N/A	N/A N/A	
	B	Upper floor	N/A	Natural Ventilated N/A	

5. Fire Extinguisher:				
A	Total numbers	12 nos.	36 nos. /	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each Branch	02 nos Mezzanine level, 04 nos Concourse level, 04 nos Platform level	02 nos Mezzanine level, 04 nos Concourse level, 04 nos. Platform level	MR
B	Length of hose reel hose	45 mtrs	45 mtrs /	MR
C	Nozzle diameter	6.5 mm	6.5 mm /	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	Heat of Smoke	Smoke	MR
B	Location of main panel	Mezzanine level	Mezzanine level	MR
C	Location of repeater panel	Concourse level	Concourse level	MR
D	Alternate source of power	Battery & D.G. Set	Provided	MR
E	Hooter's Location	N/A	N/A	N/A
8	MOEFA:	Required	Provided	MR
9	Public Address System:	Required	Provided	MR
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm /	MR
B	Number of hydrants per Branch	02 nos mezzanine level 04 nos concourse level 04 no. platform level	02 nos mezzanine level 04 nos concourse level 04 no. platform level	MR
C	Hose box per floor	As above	As above	MR
12 Yard Hydrants:				
A	Total number of hydrants	02 nos.	02 nos. /	MR
B	Hose box	02 nos.	02 nos.	MR
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	1800 LPM	1800 LPM /	MR
B	Head of main pump	70 mtrs.	70 mtrs. /	MR
C	Number of main pumps	01 no.	01 no. /	MR
D	Jockey pump out put	180 LPM	180 LPM	MR
E	Jockey pump head	70 mtrs	70 mtrs /	MR
F	Standby pump out put	1800 LPM	1800 LPM /	MR
G	Standby pump head	70 mtrs.	70 mtrs. /	MR
H	Auto starting /manual stopping	Required	Provided	MR
2 Terrace Level				
A	Discharge of pump	N/A	N/A	N/A
B	Head of the pump	N/A	N/A	N/A
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided /	MR

W


✓

14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	50,000 liters.	50,000 liters ✓	MR
	B	Draw-off connection	Required	Provided	MR
	C	Fire service inlet	Required	Provided	MR
	D	Access to tank	Required	Provided ✓	MR
	E	Overhead tank capacity	10,000 liters	10,000 liters	MR
15	Exit Signage:				
16	Provision of Lifts:				
	A	Pressurization of lift shaft	N/A	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A	N/A
	C	Communication in lift car	Required	Provided ✓	MR
	D	Firemen's switch	Required	Provided ✓	MR
	E	Lift signage	Required	Provided ✓	MR
17	Standby Power Supply:				
18	Refuge Area:				
	A	Total area	N/A	N/A	N/A
	B	Location	N/A	N/A	N/A
19	Fire Control Room:				
	A	Detector system panel	Required	Provided	MR
	B	Flow switch panel	Required	Provided	MR
	C	PA system panel	Required	Provided ✓	MR
	D	Battery backup	Required	Provided ✓	MR
	E	Building floor plans	Required	Provided ✓	MR
20	Special Fire Protection System for Protection of special Risks, if any: Novec 1230 clean agent.				MR

The fire protection systems provided in the building were randomly tested/checked and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in under the rules the FSC issued vide letter no. **F6/DFS/MS/DMRC/NDZ/2021/452** dated **17/09/2021** is recommended to be renewed.

No File is pending with me before disposal of this case.


 18/7/2024
 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)


~~DY. CEO/NDZ~~

King
 19/07/24
 C.F.O.
 19/7/2024
 Director
 19/07/24

Sir,

F. T Letter is put up for sign. Please

Director
 22/7/24


 22/7/2024