



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2024/WZ/ 457

Dated: 23/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **Netaji Subhash Place Metro Station, Line-1** located at **Wazirpur, New Delhi-110034** comprised of **Ground + Concourse Level + Platform (Except PD Area)** owned/occupied by **Delhi Metro Rail Corporation Ltd.** was issued fire safety certificate vide **Letter No. F6/DFS/MS/WZ/2021/295 dated 07/07/2021** have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on **15/07/2024** in the presence of **Sh. Vikas Bhardwaj (Manager/ Fire)** and that the building premise is fit for occupancy under "Assembly Building Group D, Sub Division D-7" (Except PD Area) with effect from **23/07/2024** for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **23/07/2024** at New Delhi by

(Atul Garg)
Director

Ph. 011-23414000

Atul Garg

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Copy to :-

1. Sh. Malay Saha (GM, E & M), Metro Bhawan, 13 Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

N-34
INSPECTION REPORT

1. Name & address of the building : Netaji Subhash Place Metro Station, Line-1, (Except PD Area) located at Wazirpur, Delhi-110034.
 2. Type of Occupancy : Assembly.
 3. Building Comprised of : Ground (PD Area) + Mezzanine(PD Area) + Metro Station at Upper floor
 4. Type of Case : Renewal (Ground + Concourse + Platform) except PD area.
 5. Details of Previous NOC : F6/DFS/MS/WZ/2021/295 Dated- 07/07/2021
 6. Fire Safety directives letter No : F6/DFS/MS/BP/2004/2134 Dated- 16/09/2004 & F6/DFS/MS/BP/2005/1258 Dated- 13/06/2005
 7. Date of inspection : 15/07/2024
 8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
 9. Name and designation of officers : Sh. Vikas Bhardwaj (Manager/ Fire)
 10. Year of Construction : 2005
 11. Applicant's letter No. : DMRC/O&M/Fire/NOC/L-1/2024/05 dated 25/06/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ NFPA/ Requirement letter dated- 07/07/2021	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	24 m & 13.5 m side road	Provided	MR
	Gate width	5 m	Provided	MR
	Width of internal road	6 m	5 m to 6 m	MR(old case)
2.	Number, Width, Type & Arrangement of Exits			
	Number of staircases			
	Upper Floors	04	P.F. to Conc.- 04, Conc. to Gr.- 02, (2 Nos. PD Area)	MR(old case)
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	1.5 m each	2.61 m each & (2 m ,1.5 m PD area)	MR(old case)
	Basements	NA	NA	NA
	Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	01	Service staircase	MR(old case)
	Width of Corridor	NA	NA	NA
	Door Size	2 m & 1.5 m	Provided	MR
3.	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire Rating of shaft door	Required	Provided	MR
	Water Curtain	NA	NA	NA
	Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	Basements	NA	NA	NA
	Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	Total numbers	20 Nos.	Provided	MR
	Types	CO2 & WCo2	Provided	MR
	IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	04 Nos. each at P.F. & Conc.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	Type of detectors	Smoke & Heat	Provided	MR
	Location of Main Panel	SCR	Provided	MR

N-35

Detector
Flow Sv

	Location of Repeater Panel	Required	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	Basement	NA	NA	NA
	Upper Floor	NA	Provided in PD area	NA
	Sprinkler above false ceiling	NA	Provided in PD area	NA
11.	Internal Hydrants			
	Size of riser/down-comer	150 mm	Provided	MR
	Number of hydrants per floor	04 Nos. each on P.F. & Con.	Provided	MR
	Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	Total number of hydrants	07	Provided	MR
	Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	1800 lpm	Provided	MR
	Head of Main pump	40 m	Provided	MR
	Number of main pumps	02	Provided	MR
	Jockey Pump out put	180 lpm	Provided	MR
	Jockey pump head	40 m	Provided	MR
	Standby Pump out put	1800 lpm	Provided	MR
	Standby Pump Head	40 m	Provided	MR
	Auto Starting/Manual Stopping	Required	Provided	MR
	Pump House Access	Required	Provided	MR
	Terrace level			
	Discharge of pump	NA	NA	NA
	Head of the pump	NA	NA	NA
	Power Supply	NA	NA	NA
	Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	100,000 ltrs	Provided	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	Required	Provided	MR
	Fireman's Grounding Switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA

07

19. Fire Control Room			
	Detector System Panel	Required	Provided
	Flow Switch Panel	Required	Provided
	PA System Panel	Required	Provided
	Battery backup	Required	Provided
	Building Floor Plans	Required	Provided
			MR
20.	Special Fire Protection System for Protection of special Risks, if any:	CO2 Flooding for ASS, HT, LT Panel	Provided
			MR

Note:- The DMRC management had applied only for Netaji Subhash Place Metro Station, Line-1, except PD area.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/WZ/2021/295 dated 07/07/2021 under rule 37 of Delhi Fire Service Rules, 2010.

Rajeev Kumar Sinha
16/7/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

~~*Director*~~

~~*16/7*~~

~~*CFO*~~
~~*18/7/2024*~~

~~*Director*~~
~~*18/7/24*~~

18/7/24
Dated: 16/7/2024

San, for letter no 1100 for you please

Rajeev Kumar Sinha
19/7/24

~~*Director*~~
~~*19/07/24*~~
rn