

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/SZ/2024/ 696

Dated: 23/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **City Heights School at Plot No. 4, 5 (A- 4, 5), Vipin Garden, Dwarka Mor, New Delhi-110059**, comprised of ground plus three upper floors but school running at ground and first floor only. Owned/occupied City Hights School was issued FSC vide letter no. F.6/MS/DFS/2007/151 dated 17.01.2007 (for ground floor only). The school building was inspected by the officer concerned of this department on dated 12.07.2024 in the presence of Mr. Sonu Ahuja (Chairman) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (for ground and first floor only) is fit for occupancy class "Educational" w.e.f. 23/07/2024 for a period of **three** years, subject to compliance of the conditions printed as under.

Issued on 23/07/2024 at New Delhi.


(Atal Garg)
 Director
 Delhi Fire Service

Copy to:-

1. The Principal, City Heights School at Plot No. 4, 5 (A- 4, 5), Vipin Garden, Dwarka Mor, New Delhi-110059.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : City Hights School at Plot No. 4, 5 (A- 4, 5), Vipin Garden, Dwarka Mor, New Delhi- 110059.
2. Building is comprised of : **Ground plus three upper floors but school running at ground & first floor only. (3rd and 4th floor not in use)**
3. Type of Occupancy : Educational
4. Type of Case : New Case/additional alteration
5. Details of Previous NOC : F.6/ MS/DFS/2007/151 dated 17.01.2007 (for ground floor only)
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 12.07.2024
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer from the building side : Mr. Sonu Ahuja (Chairman)
10. Year of Construction : 2005-06
11. Applicant's letter No : Email Id cityheightsschoolvipingarden@gmail.com dt. 03.05.2024

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirements	Provided at Site	Remarks MR/NMR	
1	Access to building				
	Road width	06 m	06 m	MR	
	Gate width	4.5 m	05 m	MR	
	Width of internal road	N.A.	N.A.	N.A.	
2	Number, Width, Type and Arrangement of Exits				
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size					
	02 no.	02 no.	MR		
	N.A.	N.A.	N.A.		
	1.50 m each	1.50 m each	MR		
	N.A.	N.A.	N.A.		
	N.A.	N.A.	N.A.		
	01 no.	01 no.	MR		
	Required	Provided	MR		
	1.0 m	1.10 m	MR		
	3	Compartmentation.			
	Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers	N.A.	N.A.	N.A.	
		N.A.	N.A.	N.A.	
N.A.		N.A.	N.A.		
N.A.		N.A.	N.A.		
N.A.		N.A.	N.A.		
4	Smoke Management System.				
Basement Upper floor	N.A.	N.A.	N.A.		
	Required	Natural Ventilation	MR		

N/3

5.	Fire Extinguisher			
	Total numbers	10 Nos.	10 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	Provided	MR
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	100 mm	N.A.
	Number of hydrants per floor	N.A.	01	N.A.
	Hose Box	N.A.	01	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	Required	Provided	MR

N/4

16 Provision of Lifts.			
Pressurization of Lift Shaft	N.A.	N.A.	N.A.
Pressurization of Lift lobby	N.A.	N.A.	N.A.
Communication in lift car	N.A.	N.A.	N.A.
Firemen's grounding switch	N.A.	N.A.	N.A.
Lift Signage	N.A.	N.A.	N.A.
17 Standby power supply	N.A.	N.A.	N.A.
18 Refuge Area.			
Total area	N.A.	N.A.	N.A.
Location	N.A.	N.A.	N.A.
19 Fire Control Room			
Detector system panel	N.A.	N.A.	N.A.
Flow switch panel	N.A.	N.A.	N.A.
PA system panel	N.A.	N.A.	N.A.
Batter backup	N.A.	N.A.	N.A.
Building Floor Plans	N.A.	N.A.	N.A.
20 Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/ MS/DFS/2007/151 dated 17.01.2007 (for ground floor only), renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

Note- As per undertaking (placed at C-07) the school building comprised of ground plus three upper floors, but school running at ground and first floor only (second & third floor not in use). Previous FSC issued vide letter No. F.6/ MS/DFS/2007/151 dated 17.01.2007 for ground floor only for New Shweta Public School.

R.K. Yadav
15/07/2011

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (South West) *[Signature]*
CFO (S2) *[Signature]*
18/7/2011
Director *[Signature]*
19/07/11

Amr/SK