

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/School/709

Dated: 23/07/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co- Ed. Senior Secondary School, Located at Sector -06, Site-II, Dwarka New Delhi - 110075. comprised of Ground + 03 Upper Floors owned / occupied by Delhi Government was issued FSC vide Letter No. /DFS/MS/SZ /2021/441, dated 06/07/2021 The premises was re inspected by the officers concerned of this department on 12/07/2024 in the presence of Dr. Seema Bhardwaj (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B "Educational" with effect from 23/07/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/07/2024.. at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service.

Copy to:

1. Govt. Co- Ed. Senior Secondary School, Sector -06, Site-II, Dwarka, New Delhi - 110075.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/18

INSPECTION REPORT

1. Name & address of the building: Govt. Co- Ed. Senior Secondary School,
Located at Sector -06, Site-II New Delhi – 110075.
2. Type of Occupancy : Educational Old building (3 BL=G+3UF attached with
each floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SZ /2021/441, dated 06/07/2021
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 12/07/2024
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Dr. Seema Bhardwaj (Principal)
9. Year of Construction : 2010
10. Applicant's letter No. : GCOED/SSS/DWK/S-VI/81, dated 25/06/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per N/11, N/12 & N/13	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible(06mtrs)	Provided	MR
	• Gate width	4.5mtrs	provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4	4 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m if less than 1.5m additional staircase of 75cm in required	Old building (3 BL- attached with each floors) 2X150cm, 1x143cm, 1x145cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	150cm	132cm to 140cm(Old case)	MR
	f. Door Size	100cm	90cm & 109cm(Double door)	MR(old case)

Handwritten signature

2/19

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural ventilation provided	MR
5.	Fire Extinguishers			
	• Total numbers	20 nos.	37 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	100mm	NA
	• Number of hydrants per floor	NA	Two	NA
	• Hose Box	NA	Provided	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	Two	NA
	• Hose Box	NA	Provided	NA

N/20

13. Pumping Arrangements:			
• Ground Level	NA	NA	NA
• Discharge of main pump	NA	NA	NA
➤ Head of main pump	NA	NA	NA
➤ Number of main pumps	NA	NA	NA
➤ Jockey pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby Pump out put	NA	NA	NA
➤ Standby Pump Head	NA	NA	NA
➤ Auto Staring/Manual stopping	NA	NA	NA
➤ Pump House Access	NA	NA	NA
• Terrace level			
➤ Discharge of pump	450 lpm	Provided	MR
➤ Head of the pump	40Mtr	Provided	MR
➤ Power supply	Required	Provided	MR
➤ Auto starting of pump	Required	Provided	MR
14. Captive water Storage for fire fighting:			
• Underground tank capacity	NA	NA	NA
➤ Draw off connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	10,000Ltrs	Provided	MR
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts			
➤ Pressurization of Lift Shaft	NA	NA	NA
➤ Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	NA	NA	NA
➤ Fireman's Grounding Switch	NA	NA	NA
➤ Lift Signage	NA	NA	NA
17. Standby power supply	NA	NA	NA
18. Refuge Area			
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA

(Handwritten signature and initials)

2-21

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--------------------------------------------------------------------------	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/SZ /2021/441, dated 06/07/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved, the FSC may be issued.

~~Signature of the Inspecting Officer~~
 Name Uday Ar Singh
 Designation MDO/DWP

~~Signature~~ 18/2/21

~~Signature~~ CFO (S2)
 Director
 18/2/21
 19/7/21
 h