



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Audi/2024/SZ/ 469

Dated: 24/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **Auditorium** at India International Centre, 40, Max Muller Marg, New Delhi-110003, comprised of Ground Floor only, owned/occupied by India International Centre was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Audi/2021/SZ/315 dated 12/07/2021. The premise was re-inspected by the officer concerned of this department on 22/07/2024 in the presence of Sh. N.R. Rajagopal (Head-MD) and observed that the fire protection and fire safety arrangements provided in the premises are in satisfactory working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premises is fit for occupancy class "**Assembly**" (Auditorium) with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/07/2024 at New Delhi by


24/07/2024
(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/08/24

Copy to: -

1. The Addl. Commissioner of Police, Licensing Unit, First Floor, Police Station Defence Colony, New Delhi-110049
2. The Authorized Signatory M/s India International Centre, 40, Max Muller Marg, New Delhi-110003

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	M/s Auditorium at India International Centre, 40, Max Muller Marg, New Delhi-110003		
2.	Type of Occupancy	Assembly (Auditorium with 231 seats)		
3.	Composition of building	Ground Floor only		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/Audi/2021/SZ/315 dtd 12/07/2021		
6.	Fire Safety directives Letter No	Nil		
7.	Date of inspection	22/07/2024		
8.	Name of the Inspecting Officer	Santosh Kumar (ADO/SJ)		
9.	Name and Designation of Officers from the building side	Sh. N.R. Rajagopal (Head-MD)		
10.	Year of Construction	1961		
11.	Applicant's letter No. Email received from ID iicadmin2@iicdelhi.in dated 09/07/2024			
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6m N/A N/A	8m N/A N/A	MR N/A N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	N/A N/A	N/A N/A	N/A N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	N/A N/A	N/A N/A	N/A N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No of continuous staircase to terrace	One	Provided	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.50m x 2	1.7m x 2 & 0.80m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A 12 ACPH	N/A Exhaust fan provided	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	ISI marked	10 nos. ABC/W.CO ₂ / CO ₂ Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Hose-reel	02nos in Audi 30m 5mm	MR MR MR

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA/MCPs	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	Fire-fighting system is common for entire complex		
	➤ Discharge of main pump	2280 LPM	2280 LPM	MR
	➤ Head of main pump	75m	75m	MR
	➤ Number of main pumps	2 Nos	2 Nos	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	75m	75m	MR
	➤ Standby Pump out put	2280 LPM	2280 LPM	MR
	➤ Standby Pump Head	75m	75m	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	35m	35m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	50,000 Ltrs	50,000 Ltrs	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 Ltrs	20,000 Ltrs	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

Sw

✓

19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	2nos CO ₂ type fire extinguishers provided in projection room.		MR

Note: Application for renewal of FSC of Auditorium received through email and inspected as per past practice. Submitted for approval please.

The fire protection systems provided in the building were checked, tested and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under, the fire safety certificate issued vide letter No. F6/DFS/MS/Audi/2021/SZ/315 dated 12/07/2021, renewal under rule 37 of Delhi Fire Service Rules, 2010, is recommended.

Accordingly, DFA is put up for approval and signature please.

Santosh Kumar
23/07/24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

msl
24/7/24

cto
23/7/24

Director

[Signature]
23/7/24

FT Ph

ADY (SJ)

Sir, F.T letter is put up for your sig. pl

Director
24/7/24

Santosh Kumar
23/07/24