



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/EH/2024/ 230

Dated: 19/07/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s ONYX (A Unit of Shots Cafe) located at Plot No.03, Ground & First floor, LSC Gujrawala Town Part-I, Delhi-110009 in the building comprised of Basement + Ground + 03 Floors owned/occupied M/s ONYX (A Unit of Shots Cafe) was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2021/WZ/301 dated 25.10.2021. The premises was re-inspected by the officers concerned of this department on 13.07.2024 in the presence of Mr. Jitender (Attendant) and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and building/ premise is fit for occupancy Class- "Group D" (Assembly) Restaurant at ground & first floor only occupancy with effect from.....19/07/2024 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...19/07/2024... at New Delhi by


(Anil Garg)
Director
Ph.-011-23414000


Copy to:-

1. M/s ONYX (A Unit of Shots Cafe) located at Plot No.03, Ground & First floor, LSC Gujrawala Town Part-I, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s ONYX (A Unit of Shots Café) at Plot No.03, GF & FF, LSC
Gujrawala Town, Part-I, Delhi-110009.
2. Type of Occupancy : Restaurant (Assembly)
3. Type of Case : Renewal
4. Composition of building : Basement, Ground & 03 upper floors but restaurant running at ground + First floor only, 2nd & 3rd floor other restaurant & basement- lying vacant (other property)
5. Details of previous NOC : F6/DFS/MS/EH/WZ/301 dated: 25.10.2021
6. Fire Safety directives letter No : BBL
7. Date of inspection : 13.07.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Jitender (Attendant)
10. Year of Construction : 2005
11. Applicant's letter No. : Online MHA Portal I D No. 2024060708958 Dated: 27.06.2024


	Minimum Standards on fire prevention and fire safety U/R 33	BBL Requirements/ Inspection dated 13.09.2013	Provided at site	Remarks MR/NMR
1	Access to building.			
	• Road width	06	08m	MR
	• Gate width	05m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	Other property	NA
	b. Width of staircases			
	• Upper Floors	1.25m each	1.40m & 1.25m	MR (being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m	MR (being old case)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	06nos	08nos	MR
	• Types	ABC/Co2	ABC-08	MR

	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01 each floor	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	Provided	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	01	Provided	MR
	• Hose Box	01	Provided	MR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	40m	Provided	MR
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	900 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA


	<ul style="list-style-type: none"> ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		5,000 LTR	Provided	MR (being old case)
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. .			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules. It is recommended to renew Fire Safety vide this department letter of even no.F6/DFS/MS/EH/2021/WZ/301 dated 25.10.2021 Certificate under rule 37(3) of Delhi Fire Service Rules 2010.



 Signature of the Inspecting Officer
 Name: - C.L. Meena
 Designation:- ADO/RN

DO (NW)


16/07/2024


Dy CFO (NW)


16/7

CFO

18/7/2024

Director

19/7/24



Uploaded
20/7/24

Dy CFO
Dated: 16/7/2024