


062



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2024/School/ 693

Dated: 23/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that Sarvodaya Kanya Vidyalaya (School I.D No-1309028/1309012) located at Rana Pratap Bagh, Delhi-110007 comprised of 05 blocks, 02 New block comprised of Ground + 03 upper floor each & 03 Old blocks comprised of ground + first floor each only owned/ occupied by Sarvodaya Kanya Vidyalaya was granted FSC by this department vide letter No.F6/DFS/MS/2020/WZ/361 dated 22.09.2020 (old block, ground & first floor) and letter No. F6/DFS/MS/2021/School/901 dated 27.10.2021 (new block, ground + 03 upper floors). The premises was re-inspected by the officer concerned of this department on 06.07.2024 in presence of Smt. Mukesh Chauhan (Vice-Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under Educational "Group B" with effect from .....23/07/2024 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on ...23/07/2024... at New Delhi by

(Atul Garg)  
Director  
Ph:-011-23414000  
etc

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Vice-Principal, Sarvodaya Kanya Vidyalaya (School I.D No-1309028/1309012) located at Rana Pratap Bagh, Delhi-110007 .

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

### INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya located at Rana Pratap Bagh, Delhi-110007.  
(School I.D No.1309028/1309012)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 05 blocks, 02 New blocks, comprised of Ground + 03 upper floors & 03 old blocks, Comprised of ground + first floors only
5. Details of previous NOC : F6/DFS/MS/2020/WZ/361 dated 22.09.2020 (Ground + first floor)  
F6/DFS/MS/2021/School/901 dated 27.10.2021
6. Fire Safety directives letter No : NBC Part-4/Director of education dated 01.03.2011
7. Date of inspection : 06.07.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Smt. Mukesh Chauhan (Vice-Principal)
10. Year of Construction : 2020 (new block) & 1963 (old block)
11. Applicant's letter No. : Online E-Mail I.D dated: 24.06.2024


	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements/ Director of education dated 01.03.2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	05m	5.50m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	New block 02 Old block 01 each block	04 nos 06 nos	MR
	• Basements	NA	NA	NA
	<b>b. Width of staircases</b>			
	• Upper Floors	New block, 1.50m Old block, 1.50m	1.60m each 04 nos. of 1.50m, 1.75m & 1.25m	MR
	• Basements	NA	NA	NA
	<b>c. Protection of exits</b>			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	02	02	MR	
e. Width of Corridor	1.5m	1.60m	MR	
f. Door Size	New block, 1.20m Old block, 01m	1.20m double door & old block, 90cm & 93cm	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	28nos	47nos +20nos	MR

		ABC/Co2	ABC-38 + 20 & Co2-09	MR
	<ul style="list-style-type: none"> <li>Types</li> <li>ISI marking</li> </ul>	ISI Marked	Provided	MR
6	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	02 each floor	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30m	30m	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
13	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> </ul>	N/A	450 LPM	N/A
		N/A	40m	N/A
		N/A	01	N/A
		NA	NA	NA
		NA	450 LPM	NA
		N/A	40m	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	450 LPM	450 LPM each for G+ 03 block	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
	14	<b>Captive Water Storage for fire fighting</b>		
<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>		NA	80,000 LTR	NA
<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>		NA	NA	NA

	<ul style="list-style-type: none"> <li>▶ Fire service inlet</li> <li>▶ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		10,000 LTR each For G+03 block	10,000 LTR each For G+03 block	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>▶ Total Area</li> <li>▶ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.


Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4/Director of education the FSC issued vide letter of even No. F6/DFS/MS/2020/WZ/361 dated 22.09.2020 (old block, ground & first floor) and F6/DFS/MS/2021/School/901 dated 27.10.2021 (new block, ground + 03 upper floors) renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

  
 Signature of the Inspecting Officer  
 Name :- C.L. Meena  
 Designation:- ADO/RN

DO (NW)

  
15/07/2024

Dy cfo (02)

  
16/07/2024

Director (NW)  
16/07/2024



CFO-24  
 Dated: 15/07/2024