



No F 6 / DFS / MS / 2024 / School / WZ / 701

Dated 23/07/2024

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya located at Tulsi Nagar, Delhi- 110035 comprised of 02 Blocks interconnected (A Block- Ground plus first floor) & (B- Block- Ground plus three upper floors) owned/ occupied by Sarvodaya Kanya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with DOE circular no. 3298-3398 dated 01.03.2011 and verified by the officers concerned of Fire Service on 11.07.2024 in the presence of Sh. Rakesh Kumar Jaiswal (Principal) and found that the building/ premises is fit for occupancy Group B Educational with effect from 23/07/24 for a period of 03 (Three) years subject to compliance of the conditions mentioned below:

Issued on ... 23/07/2024 ... at New Delhi by

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Sarvodaya Kanya Vidyalaya located at Tulsi Nagar, Delhi- 110035.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Tulsi Nagar , Delhi- 110035.
2. Type of Occupancy : Educational
3. Building Comprised of : 02 Blocks (01 Blocks, G+1) & 01 Block (G+ 3) Interconnected in H Shape
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : DOE circular No. 3298-3398 dated 01/03/2011
7. Date of inspection : 11/07/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Dr. R.K. Jaiswal (Principal)
10. Year of Construction : 1976
11. Applicant's letter No. : Diary No. 3707 dated 02/07/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	Provided	MR
	Gate width	4.5 m	Directly Accessible	MR
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	Number of staircases			
	Upper Floors	02	03	MR
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	1.50 m each	2 m, 1.40 m & 1.35 m	MR
	Basements	NA	NA	NA
	Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	Required	Provided	MR
	Width of Corridor	NA	NA	NA
	Door Size	1 m	1 m, Double Door with door fitting	MR
3.	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	NA	NA	NA
	Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	Total numbers	1 @ 300 sqm	Provided	MR
	Types	ABC Type	Provided	MR
	IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	01 in each block	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA

N-14

9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	Basement	NA	NA	NA
	Ground Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	Size of riser/down-comer	NA	100 mm, Provided	NA
	Number of hydrants per floor	NA	01 in each block	NA
	Hose Box	NA	01 in each block	NA
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	450 lpm	Provided	MR
	Head of the pump	40 m	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The School management had rectified the shortcomings issued vide letter number F6/DFS/MS/WZ/2024/273 dated 28/05/2024.

Note: Electric meter and electrical panel are not under the staircase.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to grant Fire Safety Certificate.

[Handwritten Signature]
12/7/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

~~Dicfo (6/2)~~

~~[Signature]~~
16/7

~~CPD~~
18/7/2024

~~Director~~
10/07/24

Srv. f-T letter in photo on sign place

[Handwritten Signature]
19/7/24

~~Director (S)~~
19/7/24

[Handwritten mark]

FO/102-NIS.....

ated..16.07.24....