



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**



No. F6/DFS/MS/2024/School/ 690

Dated: 22/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the S.D. Juniors Play School located at C-Block, Rajiv Gandhi Road, Swaroop Nagar, Delhi-110042 comprised of basement, Ground & 03 upper floors owned/occupied by the S.D. Juniors Play School have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 12.07.2024 in the presence of Mr. Karmjeet Singh (Chairmen) and that the building/premises is fit for occupancy Class "Group B Educational" for ground & 03 upper floors only with effect from 22-07-2024 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22-07-2024 at New Delhi

(Atul Garg)  
Director  
Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Director, S.D. Juniors Play School at C-Block, Rajiv Gandhi Road, Swaroop Nagar, Delhi-110042.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : S.D. Juniors Play School at C-Block, Rajiv Gandhi Road, Swaroop Nagar, Delhi-110042.
2. Composition of building : Basement, Ground & 03 upper floors only, but school is running at ground & Three upper floors only, basement – other property
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 12.07.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Karmjeet Singh (Chairmen)
10. Year of Construction : 2022
11. Applicant's letter No. : Online E-mail dated 27.06.2024

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part 4 Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	other property	NA
	b. Width of staircases			
	• Upper Floors	1.50m each	1.50m & 1.50m (iron)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.50m	1.80m	MR
	f. Door Size	1.20m	1.30m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	10nos	10nos	MR
	• Types	ABC/CO2	ABC---10	MR
		ISI Marked	Yes	MR




	<ul style="list-style-type: none"> <li>• ISI marking</li> </ul>			
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01 at each floor	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30m	30m	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	NA	Provided	NA
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	NA	Provided	NA
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	NA	01	NA
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	NA	01	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
	14	<b>Captive Water Storage for fire fighting.</b>		
<ul style="list-style-type: none"> <li>• Underground tank capacity</li> </ul>		NA	NA	NA
<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>		NA	NA	NA
<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>		NA	NA	NA
<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>		NA	NA	NA
<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>		10,000ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR


16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2023/School/320 dated 09.08.2023.


Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


  
 Signature of the Inspecting Officer  
 Name:-C.L. Meena  
 Designation:- Asst. Div. Officer (RN)

DO (NW)

  
15/07/2024

Dy C/O (W2)

  
18/7

C/O  
  
18/7/2024

Director  
  
16/9/24

  
A.O. / RN

A-15  
dated 18/7/2024

CONF. ... P.T.O.