

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/472

Dated: 24/07/2024

FIRE SAFETY CERTIFICATE

Certified that the building Shri Banarsidas Chandiwala Sewa Samarak Trust Society, Located at Opp Metro Station Sector-11 Dwarka New delhi 110075 comprised of Basement+ Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/School/SZ/2021/63 Dated 25/01/2021. The premises was re inspected by the officer concerned of this department on 15/07/2024 in the presence of Dr. Aparna Mishra (Director) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B "Educational" with effect from 24/07/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/07/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service
24/07/24

Copy to:-

1. Dr. Aparna Mishra (Director) Shri Banarsidas Chandiwala Sewa Samarak Trust Society, Located at Opp Metro station sector-11 Dwarka new delhi-110075.
2. The, Directorate Of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Shri Banarsidas Chandiwala Sewa Samarak Trust Society, Located at Opp. Metro station sector-11 Dwarka New Delhi
2. Type of Occupancy : Educational (Basement +Ground + 3 Upper Floors)
3. Type of Case :Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2021/63 Dated 25/01/2021
5. Fire Safety directives Letter No : F6/DFS/MS/2004/BP/243 dated 29/01/2004
6. Date of inspection : 15/07/2024
7. Name of the Inspecting Officer : ADO (DWK)

No. of Students=432
No. of class rooms=10
Covered area=2669m ²
8. Name and designation of Officer
 from the building side : Dr. Aparna Mishra (Director)
9. Year of Construction : 2006
10. Applicant's letter No. : BCIPS/Admin/F.No-164/2024-25/56, dated 13/05/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/17, N/18, N/19 & N/20	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	20 mtrs	Provided	MR
	• Gate width	06 mtrs	provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	3 Provided	MR
	• Basements	2+1 ramp	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m each	1.5m each	MR
	• Basements	1.5 m	3X1.5m & 1X1.20m	MR(Being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	03 nos	03 nos	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m to 1.5 m	1 m to 1.5 m	MR(Being Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Exhaust Fans	MR
	• Upper floors	NA	NA	NA



5.	Fire Extinguishers			
	• Total numbers	30 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	3nos	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Near Stairs	Provided	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	3Nos.	3Nos.	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

(Handwritten signature)

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50000 ltr	50000 ltr	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10000 ltr each block	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 Fire Extinguisher Provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/SZ/2021/6 3 dated 25/01/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved, the FSC may be issued.

Signature of the Inspecting Officer

Name Uday Vir Singh

Designation ADP/DP/24

[Signature] 22/1/24

Cfo/(52) [Signature]
23/1/2024

Director [Signature]
27/1/24

[Signature]