

c/36



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आफ़ादीय
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 710

Dated: 24/07/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s S.S. Khalsa Senior Secondary School (ID- 1925195), located at Lajpat Nagar- IV, New Delhi-24, comprised of Ground + 01 upper floor was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2021/SZ/515 dated 20.07.2021. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 19.07.2024 in the presence of Mr. Sudhakar (Principal) and found that building has deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Directorate of Education and the building (Ground + 01 upper floor) is fit for occupancy of Group B "Educational Building" with effect from 24/07/2024.. renewed for a period of three years, subject to conditions printed below.

Issued on... 24/07/2024at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

DL
19/7/24 ✓

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, M/s S.S. Khalsa Senior Secondary School (ID- 1925195), located at Lajpat Nagar- IV, New Delhi-24.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.

2/21
INSPECTION REPORT

1	Name and address of the building:	S.S. Khalsa Senior Secondary School (ID-1925195), located at Lajpat Nagar- IV, New Delhi-24.			
2	Building is comprised of	Ground + 1 upper floor			
3	Type of occupancy	Educational Building (Group -B)			
4	Type of case:	Renewal			
5	Details of previous FSC:	F6/DFS/MS/School/2021/SZ/515 dated 20.07.2021			
6	Fire safety directives no.:	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011			
7	Date of inspection:	19.07.2024			
8	Name of the inspecting officer:	ADO Rajesh Kumar Shukla (M. Road)			
9	Name and designation of the officer from the building side:	Mr. Sudhakar (Principal)			
10	Year of construction:	2009-10			
11	Reference letter no.:	Email dated 09.07.2024			
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirements as per DOE circular dated 01.03.2011	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	Accessible	Accessible	MR
	B	Gate width	NA	4.5 m	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a) Upper floor	Required	04 nos.	MR
		b) Basements	NA	NA	NA
	B	Width of the staircase:			
		a) Upper floor	1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required.	1.46 m, 1.44 m, 1.36 m & 1.33 m	MR
		b) Basements	NA	NA	NA
	C	Protection of exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	Required	Provided	MR
	F	Width of the corridor	1.50 m	Provided	MR
	E	Door size	1.0 m for class room	Provided	MR
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Upper floors	12 a/c per hour	NA	NA
	B	Basements	30 a/c per hour	NA	NA
5	Fire Extinguishers				
	A	Total numbers	12 nos.	12 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR

2/22

6	First Aid Hose reel			
A	Total no. at each floor	NA	NA	NA
B	Length of hose reel	NA	NA	NA
C	Nozzle diameter	NA	NA	NA
7	Automatic Fire Detection and Alarm System (ADAS)			
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate power source	NA	NA	NA
E	Hooter's location	NA	NA	NA
8	MOEFA			
9	Public Address System			
10	Automatic Sprinkler System			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants			
A	Size of the riser/down comer	NA	NA	NA
B	No. Of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12	Yard Hydrants			
A	Total no. of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	Pumping Arrangements			
A	Ground Level			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pump	NA	NA	NA
d)	Discharge of jockey pump	NA	NA	NA
e)	Head of jockey pump	NA	NA	NA
f)	Discharge of standby pump	NA	NA	NA
g)	Head of standby pump	NA	NA	NA
h)	Auto starting/ manual stopping	NA	NA	NA
B	Terrace Level			
a)	Discharge of terrace pump	NA	NA	NA
b)	Head of terrace pump	NA	NA	NA
c)	Alternate power supply	NA	NA	NA
d)	Auto starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting			
A	Underground tank capacity	NA	NA	NA
B	Draw off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
E	Access to tank	NA	NA	NA
D	Overhead tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16	Provision of lift			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Fireman switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply	NA	NA	NA


18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire detection system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any	NA	NA	NA


LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided But Not Functional (PNF).


The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.


The shortcoming issued to the building by this department vide letter no. F6/DFS/MS/School/SZ/2024/327 dated 12.06.2024 has been rectified by the school management.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular no. 3298 to 3398 dated 01.03.2011, the FSC issued vide letter no. F6/DFS/MS/School/2021/SZ/515 dated 20.07.2021 is recommended to be renewed.


 Signature of the Inspecting Officer
 Name Rajesh Kumar Shukla
 Designation ADO (M. Road)

DO (SD)

 24/7/24

CFO

 22/07/2024

Director

 23/07/24

