

c-26

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2024/SZ/ 715

Dated: 25/07/2024

FIRE SAFETY CERTIFICATE

Certified that the building Ramjas School Located at Anand Parbat, New Delhi – 110005 having two blocks comprised of Ground floor & Ground + One Upper Floor was issued Fire Safety Certificate issued by this department vide letter No. F.6/DFS/MS/School/2021/SZ/562 dated 29/07/2021. The premises was inspected by the officer concerned of this department on 12/07/2024 in the presence of Mr. Vikas (Officiating Principal) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class B “Educational building” with effect from 25/07/2024 for a period of three years, subject to condition given below.

Issued on .. 25/07/2024 . at New Delhi by.

(Atul Garg)
 Director
 Delhi Fire Service

Copy to:

1. The Principal, Ramjas School Located at Anand Parbat, New Delhi – 110005.
2. The Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/18

INSPECTION REPORT

1. Name & address of the building: Ramjas School Located at Anand Parbat,
New Delhi - 110005.

2. Type of Occupancy : Educational 02 blocks (Ground floor & G+1UF)

3. Type of Case : Renewal

4. Details of previous NOC : F.6/DFS/MS/School/2021/SZ/562 dated 29/07/21

5. Fire Safety directives L. No. : DOE Circular 3298 -3398 Dated 01/03/2011

6. Date of inspection : 12/07/2024

7. Name of the Inspecting Officer : ADO (DWK)

No. of Students=1134
No. of class rooms=27
Plot area=12226m²

8. Name and designation of Officer

from the building side: : Mr. Vikas (Officiating Principal)

9. Year of Construction : Before 2010

10. Applicant's letter No. : Form J dated 25/06/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per N/14, N/15 & N/16 | Provided at site | Remarks MR/NMR |
|------|---|--------------------------|----------------------|---------------------|
| 1. | Access of building | 06 mtrs | 6 mtr | MR |
| | • Road width | 4.5m | Provided | MR(Being old case) |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | 3 No's | Provided | MR |
| | • Upper floors | NA | NA | NA |
| | • Basements | | | |
| | b. Width of staircases | | | |
| | • Upper floors | 1.5m or less & 0.75m | 1.52m, 1.30m & 1.08m | MR (Being Old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 01 | 01 | MR |
| | e. Width Of Corridor | Old case | 2.40m | MR |
| | f. Door Size | 1 mtr | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |

N/20

| | | | | |
|-----|--|----|----|----|
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no: F.6/DFS/MS/School/2021/SZ/562 dated 29/07/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved the FSC may be issued.

Signature of the Inspecting Officer
 Name Uday V Singh
 Designation ADP/DCR

[Signature]
 15/8/24
 Cfo (SZ)
[Signature]
 16/8/2024
 Director
[Signature]
 16/8/24

Sir AP letter is put up for Sir's file
[Signature]
 16/8/24
[Signature]
 16/8/24