



No. F6/DFS/MS/GH/SZ/2024/ 285

Dated: 12/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **Barkat Home Guest House** located at 7, **Basti Hazarat Nizamuddin, New Delhi**, comprised of **Basement /Lower Ground + Ground floor + 02 upper floors: Basement/lower ground floor-** (storage), **Ground floor** (reception + 05 guest rooms), **1st floor-** 05 guest rooms, **2nd floor-** 05 guest rooms, was granted Fire Safety Certificate (FSC) by this department vide letter no. F6/DFS/MS/GH/2020/SZ/152 dated 31.12.2020. The building/premises was re-inspected by Assistant Divisional Officer (M. Road) from this department on 08.07.2024 in presence of Mr. Ishrat Ullah Khan (Manager) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of **"Residential Sub Division-A-1"** for total **15 Guest rooms (Ground floor-** reception + 05 guest rooms, **1st floor -** 05 guest rooms, **2nd floor-** 05 guest rooms) and valid upto 31.03.2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on12/07/2024.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

Reference: MHA Portal online application no. 2024062209797

DL
09/7/24

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

20/23

INSPECTION REPORT

1	Name & address of the building	M/s Barkat Home Guest House, 7, Basti Hazarat Nizamuddin, New Delhi- 13				
2	Building is comprised of	Basement /Lower Ground + Ground floor + 02 upper floors Basement- Storage Ground floor- reception + 05guest rooms 1 st floor - 05 guest rooms 2 nd floor- 05 guest rooms				
3	Type of occupancy	Residential Group A-1				
4	Type of case	Renewal				
5	Details of Previous FSC	F6/DFS/MS/GH/2020/SZ/152 dated 31.12.2020				
6	Fire Safety directive letter no.	Nil				
7	Date of inspection	08.07.2024				
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (M. Road)				
9	Name of the designation of officer from the building side	Mr. Ishrat Ullah Khan (Manager)				
10	Year of construction	2006-07				
11	Applicant's letter no.	MHA online application no. 2024062209797				
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement as per Rule 35 (6)	Provided at Site	Remarks MR/NMR		
1	Access to building					
	A	Road width	6 m	Provided	MR	
	B	Gate width	NA	Directly approachable	NA	
	C	Width of internal road	NA	NA	NA	
2	Number, Width, Type and Arrangement of Exits					
	A	Number of staircases				
		a	Upper floor	01 nos.	Provided	MR
		b	Basement	02 nos.	Provided	MR
	B	Width of staircases				
		a	Upper floor	1.25 m	1.25 m	MR (Old Case)
		b	Basement	1.25 m each	2.15 m & 1.25 m	MR
	C	Protection of exits				
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	Required	01 no.	MR	
	E	Width of corridor	1.0 m	Provided	MR	
	F	Door size	1.0 m	Provided	MR	
3	Compartmentation					
	A	Fire check door	NA	NA	NA	
	B	Sealing of electrical shafts	NA	NA	NA	
	C	Fire rating of shaft door	NA	NA	NA	
	D	Water curtain	NA	NA	NA	
	E	Fire dampers	NA	NA	NA	
4	Smoke Management System.					
	A	Basement	Required	Provided	MR	
	B	Upper floor	Required	Provided	MR	

20/0 N/24

5.	Fire Extinguisher				
	A	Total numbers	10 nos.	10 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	Required	ISI marked	MR
6	First-Aid-Hose Reels				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 m	Provided	MR
	C	Nozzle diameter	5 mm	Provided	MR
7	Automatic Fire Detection And Alarming System (required as per clause 7.31.viii, UBBL 2016).				
	A	Type of detectors	CO detectors	Provided	MR
	B	Location of main panel	Required	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	Audible in entire building	Provided	MR
8	MOEFA		Required	Provided	MR
9	Public Address System.		NA	NA	NA
10	Automatic Sprinkler System.				
	A	Basement	Required	Provided	MR
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants				
	A	size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants.				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements.				
	A	Ground Level			
	a	Discharge of main Pump	NA	NA	NA
	b	Head of Main Pump	NA	NA	NA
	c	Number of main pumps	NA	NA	NA
	d	Jockey pump out put	NA	NA	NA
	e	Jockey pump head	NA	NA	NA
	f	Standby pump out put	NA	NA	NA
	g	Standby pump Head	NA	NA	NA
	h	Auto Starting /Manual stopping	NA	NA	NA
	i	Pump house access	NA	NA	NA
	B	Terrace Level			
	a	Discharge of pump	450 LPM	450 LPM & 225 LPM	MR
	b	Head of the Pump	40 m	40 m each	MR
	c	Power supply	Required	Provided	MR
	d	Auto starting of pump	Required	Provided	MR

✓ 21

14	Captive Water Storage for Fire Fighting.				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	5,000 ltrs	5,000 ltrs	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		Required	Provided DG Set	MR
18	Refuge Area.				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	Fire Control Room				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	PA system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA
20	Special Fire Protection Systems For Protection Of Special Risks, If Any:		NA	NA	NA


LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

Note :- Fire Safety Certificate has been issued to the building with single staircase of 1.25 meters width as evident at N/2 & N/5. However the requirement had been changed to 02 staircases of with 1.25 each without any clarification on file. Delhi Building Bye Law 1983 was applicable at that time and 2nd staircase was required only when travel distance was not meeting the requirements.

During the current inspection single staircase of 1.25 meters width was available which meets the travel distance requirements and same may be accepted considering it an old case.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

If agreed to the note above & in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/2020/SZ/152 dated 31.12.2020 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name Rajesh Kumar Shukla
 Designation ADO (M. Road)

DO (SD)

Handwritten signature and date
 10/7/24

Handwritten signature and date
 Director 10/7/2024

Handwritten signature and text
 The upload

Handwritten text
 uploaded