

C-45

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2024/236

Dated:- 23.07.2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Bikanerwala Foods at 10181-82, First floor, Arya Samaj Road, Karol Bagh, New Delhi comprised of Basement + Ground + 01 Upper floor, Restaurant at First floor owned /occupied by M/S Bikanerwala Foods, was earlier FSC by this department vide letter No. F6/DFS/MS/EH/NDZ/2021/254 dated 27.09.2021. Now, the premises was re-inspected by officer concerned of this department on dated 09.07.24 in presence of Sh. Pradeep Jha and found that the premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises, is fit for occupancy class **Assembly Building Group-D of Sub-Division D-5, Restaurant at First floor only** and valid up to the period of three year from the date of issue in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .... 23/07/2024 ..... at New Delhi by.

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Officer

Copy to:-

1. The Commissioner, North MCD , Civic Centre , New Delhi
2. The Dy. Commissioner of Police (Lic), Ist floor, PS Defence Colony, New Delhi ID NO. 2024053108512 dated 22.06 24.
3. The Manager, M/s Bikanerwala foods 10181-82, 1<sup>st</sup> floor, Arya Samaj Road, Karol Bagh, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned. Basement shall not be used for any purpose.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

N/10  
**INSPECTION REPORT**

1. Name & address of the building:- M/S Bikanerwala foods 10181-82, first floor, Arya Samaj Road, Karol Bagh, New Delhi.
2. Type of occupancy:- Assembly Building B + Gr. + 01 Upper, Restaurant at first floor
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/EH/NDZ/2021/254 dated 27.09.2021
5. Fire safety directives No.- N/A
6. Date of inspection:- 09/07/2024
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Sh. Pradeep Jha
9. Year of construction:- Old heritage building
10. Applicant's letter No:- ID no. 2024053108512 dated 22.06 24.

| S.No.     | Minimum Standards on fire Prevention and fire safety U/R 33 | Required    | Provided at site                   | Remarks MR/NMR |
|-----------|---|-------------|------------------------------------|----------------|
| <b>1.</b> | <b>Access to Building</b>                                   |             |                                    |                |
|           | 1) Road width   | 09 mtr.     | 09 mtr.                            | MR             |
|           | 2) Gate width   | N/A         | N/A                                | N/A            |
|           | 3) Width of internal road                                   | N/A         | N/A                                | N/A            |
| <b>2.</b> | <b>Number, Width Type &amp; Arrangement of Exits</b>        |             |                                    |                |
|           | <b>A. Number of staircases</b>                              |             |                                    |                |
|           | 1. Upper floors   | 03 Nos.     | 03 Nos.                            | MR             |
|           | 2. Basements  | N/A         | N/A                                | N/A            |
|           | <b>B. Width of staircase</b>                                |             |                                    |                |
|           | 1. Upper floors   | 1.5 & 1mtr. | 2 Nos. 1.5 mtr.<br>1 Nos. 1.0 mtr. | MR             |
|           | 2. Basements  | N/A         | N/A                                | N/A            |
|           | <b>C. Protection of exits</b>                               |             |                                    |                |
|           | 1. Fire check door  | N/A         | N/A                                | N/A            |
|           | 2. Pressurization   | N/A         | N/A                                | N/A            |
|           | <b>D. No. of continuous staircase to terrace</b>            | N/A         | N/A                                | N/A            |
|           | <b>E. Width of corridor</b>                                 | N/A         | N/A                                | N/A            |
|           | <b>F. Door size</b>   | 02 mtr.     | 2.0 mtr.                           | MR             |
| <b>3.</b> | <b>Compartmentation</b>                                     |             |                                    |                |
|           | 1) Fire check door  | N/A         | N/A                                | N/A            |
|           | 2) Sealing of electrical shafts                             | N/A         | N/A                                | N/A            |
|           | 3) Fire rating of shaft door                                | N/A         | N/A                                | N/A            |
|           | 4) Water curtain  | N/A         | N/A                                | N/A            |
|           | 5) Fire Dampers   | N/A         | N/A                                | N/A            |
| <b>4.</b> | <b>Smoke Management System</b>                              |             |                                    |                |
|           | 1) Basements  | N/A         | N/A                                | N/A            |
|           | 2) Upper floors   | 12a/c per   | Natural                            | MR             |
| <b>5.</b> | <b>Fire Extinguishers</b>                                   |             |                                    |                |
|           | 1) Total numbers  | 04          | 08                                 | MR             |
|           | 2) Types  | ABC & CO2   | ABC & CO2                          | MR             |
|           | 3) ISI marking  | ISI         | Provided                           | MR             |

✓/11

|            |   |          |             |     |
|------------|---|----------|-------------|-----|
| <b>6.</b>  | <b>First-Aid Hose Reel</b>                            |          |             |     |
|            | 1) Total number each floor                            | 01       | 01          | MR  |
|            | 2) Length of hose reel hose                           | 30 m     | 30 m        | MR  |
|            | 3) Nozzle diameter                                    | 5 mm     | 5 mm        | MR  |
| <b>7.</b>  | <b>Automatic Fire Detection &amp; Alarming System</b> |          |             |     |
|            | 1) Type of detectors                                  | N/A      | Provided    | N/A |
|            | 2) Location of main panel                             | N/A      | First floor | N/A |
|            | 3) Location of repeater panel                         | N/A      | N/A         | N/A |
|            | 4) Alternate source of power                          | N/A      | Provided    | N/A |
|            | 5) Hooter's Location                                  | N/A      | First floor | N/A |
| <b>8.</b>  | <b>MOEFA</b>  | Required | Provided    | MR  |
| <b>9.</b>  | <b>Public Address System</b>                          | N/A      | N/A         | N/A |
| <b>10.</b> | <b>Automatic Sprinkler System</b>                     |          |             |     |
|            | 1) Basement   | N/A      | N/A         | N/A |
|            | 2) Upper floors, 1 <sup>st</sup> floor                | Required | Provided    | MR  |
|            | 3) Sprinkler above false ceiling                      | N/A      | N/A         | N/A |
| <b>11.</b> | <b>Internal Hydrants</b>                              |          |             |     |
|            | 1) Size of riser/down-comer                           | 100 mm   | 100 mm      | MR  |
|            | 2) Number of hydrants                                 | 01       | 01          | MR  |
|            | 3) Hose box   | 01       | 01          | MR  |
| <b>12.</b> | <b>Yard Hydrants</b>                                  |          |             |     |
|            | 1) Total number of hydrants                           | N/A      | N/A         | N/A |
|            | 2) Hose box   | N/A      | N/A         | N/A |
| <b>13.</b> | <b>Pumping Arrangement</b>                            |          |             |     |
|            | 1) Ground level                                       |          |             |     |
|            | a) Discharge of main pump                             | N/A      | N/A         | N/A |
|            | b) Head of main pump                                  | N/A      | N/A         | N/A |
|            | c) Number of main pump                                | N/A      | N/A         | N/A |
|            | d) Jockey pump out put                                | N/A      | N/A         | N/A |
|            | e) Jockey pump head                                   | N/A      | N/A         | N/A |
|            | f) Stand by pump output                               | N/A      | N/A         | N/A |
|            | g) Stand by pump head                                 | N/A      | N/A         | N/A |
|            | h) Auto starting/Manual stopping                      | N/A      | N/A         | N/A |
|            | 2) Terrace level                                      |          |             |     |
|            | a) Discharge of pump                                  | 450 LPM  | 450 LPM     | MR  |
|            | b) Head of pump                                       | 40 mtr.  | 40 mtr.     | MR  |
|            | c) Power supply                                       | Required | Provided    | MR  |
|            | d) Auto starting of pump                              | Required | Provided    | MR  |
| <b>14.</b> | <b>Captive Water Storage for Fire Fighting</b>        |          |             |     |
|            | 1) Under ground tank capacity                         | N/A      | N/A         | N/A |
|            | a) Draw-off connection                                | N/A      | N/A         | N/A |

✓ ✓ ✓

|     |   |              |             |     |
|-----|---|--------------|-------------|-----|
|     | b) Fire service inlet   | N/A          | N/A         | N/A |
|     | c) Access to tank   | N/A          | N/A         | N/A |
|     | d) Over head tank capacity  | 10,000 ltrs. | 15,000 Ltr. | MR  |
| 15. | <b>Exit Signage.</b>  | Required     | Provided    | MR  |
| 16. | <b>Provision of Lifts.</b>  |              |             |     |
|     | a) Pressurization of lift shaft   | N/A          | N/A         | N/A |
|     | b) Pressurization of lift lobby   | N/A          | N/A         | N/A |
|     | c) Communication in lift car  | N/A          | N/A         | N/A |
|     | d) Fireman's switch   | N/A          | N/A         | N/A |
|     | e) Lift signage   | N/A          | N/A         | N/A |
| 17. | <b>Stand by Power Supply</b>  | Required     | Provided    | MR  |
| 18. | <b>Refuge Area</b>  | N/A          | N/A         | N/A |
|     | Total area location   | N/A          | N/A         | N/A |
| 19. | <b>Fire Control Room</b>  | N/A          | N/A         | N/A |
|     | a) Detector system panel  | N/A          | N/A         | N/A |
|     | b) Flow switch panel  | N/A          | N/A         | N/A |
|     | c) PA system panel  | N/A          | N/A         | N/A |
|     | d) Battery backup   | N/A          | N/A         | N/A |
|     | e) Building floor plan  | N/A          | N/A         | N/A |
| 20. | <b>Special Fire Protection System for Protection of special Risk, if any:</b> |              |             | MR  |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F F6/DFS/MS/EH/NDZ/2021/254 dated 27.09.2021, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval please.

Signature of the Inspecting Officer



Name :- Ravinder Singh  
Designation :- ADO (CC)

Dated  
18/7/24  
Dy. C.F.O. (M2)  
C.F.O.  
22/7/2024  
Director  
23/7/24

Recd  
19/07/24

Updated  
22/7/24