

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2024/ 722

Dated: 25/07/2024

FIRE SAFETY CERTIFICATE

Certified that DAV Sr. Sec. School/ DAV Collage Managing Committee office located at Chitra Gupta Road, New Delhi comprises of School – Ground + 01 upper floor & Admn. Block – Basement + Ground + 03 upper floor owned/occupied by DAV Sr. Sec. School/ DAV Collage ,was earlier granted FSC by this department vide letter No. F6/DFS/MS/School/NDZ/2021/419 dated 01/07/2021. Now, the premises was re-inspected by the officer concerned of this department on 12-07-2024 in the presence of Sh. Rakesh Khullar, Admin Officer and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group B “Educational Building” Sub-Div. B-I with effect from ----25/07/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on25/07/2024 at New Delhi by.

Yours faithfully

(Atul Gang)
 DIRECTOR
 Delhi Fire Service

Copy to:-

1. The Commissioner, North MCD , Civic Centre , New Delhi : to ensure the deviation in construction if any.
2. Director of Education, Govt. of NCT, Delhi.
3. Sh. Ashok Kumar Adlakha (Dir. Admn.),DAV Sr. Sec. School/ DAV Collage Managing Committee office at Chitra Gupta Road, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. The trained fire fighting staff should be available round the clock.
6. Basement shall be used as per NBC/BBL 1983.
7. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
8. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
9. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry”.
10. Any flammable material for interior decoration is prohibited.

4/4

INSPECTION REPORT

1. Name & address of the building:- DAV Sr. Sec. School/ DAV Collage
Managing Committee office at Chitra Gupta
Road, New Delhi
2. Type of occupancy:- Educational Building,
School – Ground + 01 upper floor &
Admn. Block – Basement + Ground + 03 upper floor
3. Type of case: - Renewal
4. Details of previous FSC: - F6/DFS/MS/School/NDZ/2021/419 dated
01/07/2021.
5. Fire safety directives No.- F6/DFS/MS/BP/2003/49 dated 06.01.2003
6. Date of inspection:- 24/06/21
7. Name of the inspecting officer: - Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Sh. Rakesh Khullar
9. Year of construction:- 2008-2010
10. Applicant's letter No:- letter no. 80028 dated 01.07.24

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements as per previous inspection	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	09 mtr. ✓	MR
	2) Gate width	5 mtr.	5 mtr. ✓	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	07	07 ✓	MR
	2. Basements	04	04 ✓	MR
	B. Width of staircase			
	1. Upper floors	1.25 & 1.5 mtr.	1 Nos. 1.60 mtr. 1 Nos. 1.15 mtr. 3 Nos. 1.20 mtr. 2 Nos. 1.35 mtr. ✓	MR
	2. Basements	1.25 mtr.	1.60, 1.45, 1.50 & 1.35 mtr. ✓	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01 ✓	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr. ✓	MR
	F. Door size	1.0 mtr.	1.0 mtr ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	12 ACPH	Exhaust fan	MR

M/15

	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			MR
	1) Total numbers	20 Nos.	20 Nos	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			MR
	1) Total number of each floor	03	03	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			N/A
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	MR
8.	MOEFA	Required	Provided	N/A
9.	Public Address System	N/A	N/A	
10.	Automatic Sprinkler System			MR
	1) Basement	Required	Provided	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	
11.	Internal Hydrants			MR
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	02	MR
	3) Hose box	01	02	MR
12.	Yard Hydrants			N/A
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	
13.	Pumping Arrangement			
	1) Ground level			MR
	a) Discharge of main pump	1620 LPM	1620 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	N/A
	c) Number of main pump	N/A	01nos	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	35 mtr.	35 mtr.	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 ltr.	50,000 ltr.	MR
	a) Draw-off connection	N/A	N/A	N/A

	b) Fire service inlet	Required	Provided ✓	MR
	c) Access to tank	Required	Provided ✓	MR
	d) Over head tank capacity	15,000 ltr.	15,000 ltr. ✓	MR
15.	Exit Signage.	Required	Provided ✓	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided ✓	MR
	d) Fireman's switch	Required	Provided ✓	MR
	e) Lift signage	Required	Provided ✓	MR
17.	Stand by Power Supply	Required	Provided ✓	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2021/419 dated 01/07/2021, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Signature]
16/7/24
Name: Ravinder Singh
Designation: ADO (CC)

[Signature]
16/7/24

[Signature]
Sycro (no.2)

[Signature]
18/07/24

C.F.O.

[Signature]
22/7/2024
Director

[Signature]

As approved PFI put up for kind perusal and signature please