



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTER: DELHI FIRE SERVICE: NEW DELHI- 110001

G-38  
75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2024/ 718

Dated:- 25/07/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Boys Sr. Sec. School (ID-1617015), Located at Jwalapuri (Amalwas), New Delhi-110087, comprised of 03 Blocks - Ground + 01 Upper Floors only, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2021/941 dated 17/11/2021. The said premises was re-inspected by the officer concerned of this department on 12/07/2024 in the presence of Sh. C.L. Meena (Principal) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E. Cr. No. 3298-3398 dated 01/03/2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 25/07/2024 for a period of three years, subject to compliance of the conditions, printed below.

Issued on .. 25/07/2024 .. at New Delhi by.

  
(Atul Garg)  
Director  
Tel No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Govt. Boys Sr. Sec. School (ID-1617015), Jwalapuri (Amalwas), New Delhi-110087.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name and address of the building: **Govt. Boys Sr. Sec. School, located at Jwalapuri (Amalwas), New Delhi-110087**
2. Type of Occupancy : Educational, (03 blocks - G + 01 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2021/941 Dated 17/11/2021
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 12/07/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Sh. C.L. Meena (Principal)
9. Year of Construction : 2004
10. Applicant's letter No. : GBSSS dated 20/06/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01/03/2011/ as per FSC dated 17/11/2021	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	a. Number of staircases			
	• Upper floors	02 in each block	02 in each block	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	Block 1 – 1.45 m x 2 Block 2 – 1.37 m x 2 Block 3 – 1.5 m & 1.35 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01 in each block	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1.0 m	Provided	MR
3.	<b>Compartmentation</b>		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke managements System</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA



5.	Fire Extinguishers			Provided	MR
		<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	15 nos.	Provided	MR
			ABC & CO <sub>2</sub>	Provided	MR
			ISI marked	Provided	
6.	First – Aid Hose Reels				NA
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
7.	Automatic fire detection and alarming system			NA	NA
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
8.	MOEFA	NA	NA	NA	NA
9.	Public Address System	NA	NA	NA	NA
10.	Automatic Sprinkler System			NA	NA
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
11.	Internal Hydrants:			NA	NA
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
12.	Yard Hydrants			NA	NA
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
13.	Pumping Arrangements:				
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
14.	Captive water Storage for fire fighting:				
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
15.	Exit Signage	Required	Provided	MR	MR
16.	Provision of Lifts				
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
17.	Standby power supply	NA	NA	NA	NA

18.	Refuge Area	NA	NA	NA
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room	NA	NA	NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2021/941 Dated 17/11/2021 is recommended.

Accordingly DFA is prepared for approval & signature please.

*1 Q1111 H*  
*16/07/24*  
 Aman Kumar Lathar  
 ADO (JWP)

*DCFO (WZ)*

*[Signature]*  
*18/7/2021*

*CFO*  
*[Signature]*  
*18/7/2021*

*Director*  
*[Signature]*  
*19/7/21*  
*ADP/ADP*

*237*  
*18/7/2024*

*Sir,*  
*F-i letter is put-up for your signature.*

*Director*  
*[Signature]*  
*23/7/24*

*1 Q1111 H*  
*23/07/24*  
 ADP (MP)