



FIRE SAFETY CERTIFICATE

Certified that the **Guru Nanak Girls Sr. Sec. School** located at **Gandhi Nagar, Delhi-110031**, comprised of Ground + 03 upper floors. (School running at ground plus two upper floors only) owned/occupied by **Guru Nanak Girls Sr. Sec. School**, was issued Fire Safety Certificate by this department vide letter No. **F6/DFS/MS/School/2021/NDZ/647** dated **25/08/2021**. The School building was re-inspected by the officer concerned of this department on 11/07/2024 in presence of Mrs. Bhupinder Kaur (H.O.S) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular letter No. 262-362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building"** with effect from 25/07/2024 for a period of **three years**, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 25/07/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

O/S DELHI FIRE SERVICE

Copy to: -

1. The Joint Director of Education (Land & Estate), Directorate of Education, Lucknow Road, Delhi-110054.
2. The Principal, Guru Nanak Girls Sr. Sec. School located at Gandhi Nagar, Delhi-110031.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

9/16

INSPECTION REPORT

1	Name & address of the building	Guru Nanak Girls Sr. Sec. School located at Gandhi Nagar, Delhi-110031.		
2	Building is comprised of	Ground + 03 upper floors. (School running at ground plus two upper floors only)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2021/NDZ/647 dated 25/08/2021		
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	11/07/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs. Bhupinder Kaur (H.O.S)		
10	Year of construction	1960		
11	Applicant's letter no.	Outdoor dairy no. 3603 dated 01/07/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Old Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A	Road width	6.0 mtrs.	06 mtrs. ✓ MR
	B	Gate width	N/A	N/A N/A
	C	Width of internal road	N/A	N/A N/A
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
	a	Upper floor	02 nos.	02 nos. ✓ MR
	b	Basement	N/A	N/A N/A
	B	Width of staircases		
	a	Upper floor	1.5 mtrs.	1.10 mtrs. & 1.0 mtr. ✓ MR (Accepted earlier)
	b	Basement	N/A	N/A N/A
	C	Protection of exits		
	a	Fire check door	N/A	N/A N/A
	b	Pressurization	N/A	N/A N/A
	D	No. of continuous staircases to terrace	01 no.	01 no. ✓ MR
	E	Width of corridor	1.50 mtrs.	1.50 mtrs. ✓ MR
	F	Door size	1.0 mtr.	1.0 mtr. ✓ MR
3	Compartmentation:			
	A	Fire check door	NA	NA NA
	B	Sealing of electrical shafts	N/A	N/A N/A
	C	Fire rating of shaft door	N/A	N/A N/A
	D	Water curtain	N/A	N/A N/A
	E	Fire dampers	N/A	N/A N/A
4	Smoke Management System:			
	A	Basement	N/A	N/A N/A
	B	Upper floor	N/A	Ventilated MR

9

2/117

		06 nos.	15 nos.	MR
	B	Types	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	MR
6	First-Aid-Hose Reel:			
	A	Total numbers of each floor	01 no.	MR
	B	Length of hose reel hose	30 mtrs	MR
	C	Nozzle diameter	50 mm	MR
7	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	N/A	N/A
	B	Location of main panel	N/A	N/A
	C	Location of repeater panel	N/A	N/A
	D	Alternate source of power	N/A	N/A
	E	Hooters	Provided	MR
8	MOEFA:			
			Provided	MR
9	Public Address System:			
			Provided	MR
10	Automatic Sprinkler System:			
	A	Basement	N/A	N/A
	B	Upper floor	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A
11	Internal Hydrants:			
	A	Size of riser/down-comer	100 mm	MR
	B	Number of hydrants per floor	01 no	MR
	C	Hose box	01 no	MR
12	Yard Hydrants:			
	A	Total number of hydrants	N/A	N/A
	B	Hose box	N/A	N/A
13	Pumping Arrangements:			
1	Ground level			
	A	Discharge of main pump	N/A	N/A
	B	Head of main pump	N/A	N/A
	C	Number of main pumps	N/A	N/A
	D	Jockey pump out put	N/A	N/A
	E	Jockey pump head	N/A	N/A
	F	Standby pump out put	N/A	N/A
	G	Standby pump head	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A
	I	Pump house access	N/A	N/A
2	Terrace Level			
	A	Discharge of pump	450 LPM	MR
	B	Head of the pump	40 mtrs.	MR
	C	Power supply	Required	MR
	D	Auto starting of pump	Required	MR

W


✓

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	5,000 litres	5,000 litres	MR
15	Exit Signage:	Required	provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	N/A	N/A	N/A
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2021/NDZ/647 dated 25/08/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.



15/7/2024

Signature of the Inspecting Officer

Name Yashwant Singh Meena

Designation ADO (L.N)

~~DY. CFO/NDZ~~

~~Diry
18/07/24~~

~~C.F.O.
19/07/2024~~

~~Director
19/07/24~~

~~AW~~