

689

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2024/School/720

Dated: 25/07/2024

FIRE SAFETY CERTIFICATE

Certified that building of Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya Located at New Rajender Nager , New Delhi-110060. comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F.6/DFS/MS/School/2015/SZ/209 dated 11/02/2015 (Issued to G+1UF) owned / occupied by Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 16/07/2024 in the presence of Dr. Hans Raj Modi (Principal) and found that the said building is fit for occupancy class "Educational" Group B Sub Division B - 1 with effect from 25/07/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 25/07/2024 at New Delhi.


(Atul Garg)
Director
Delhi Fire Service.

Copy to:

1. The Principal, Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya Located at New Rajender Nager , New Delhi-110060, School ID-2128032
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya Located at New Rajender Nager , New Delhi-110060.
2. Type of Occupancy : Educational (Ground + 02 Upper Floor)
3. Type of Case : Addition/Alteration (New Case)
4. Details of previous NOC : F.6/DFS/MS/School/2015/SZ/209 dated 11/02/2015 (Issued to G+1 UFs)
5. Fire Safety directives Letter No. : . NBC
6. Date of inspection : 16/07/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Dr. Hans Raj Modi (Principal)
9. Year of Construction : 1960& 2017-18
10. Applicant's letter No. : Email date 24/06/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	06 mtrs	MR
	• Gate width	4.5mtrs	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 No's	03 No's	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	1x1.30m & 2x 1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	150 cms	Provided	MR
	f. Door Size	100cm	1m Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation provided	MR

10

5.	Fire Extinguishers			
	• Total numbers	01 for every 300 sqm ABC & CO ₂	35 Provided	MR
	• Types	ISI marked	Co2 & ABC	MR
	• IS marking		Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	03 each floor	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010

[Handwritten Signature]
19/7/24

Signature of the Inspecting Officer
Name *Uday K Singh*
Designation *ADCPWA*

[Handwritten Signature]
22/7/24

[Handwritten Signature]
23/7/2024
[Handwritten Signature]
Director