



FIRE SAFETY CERTIFICATE

Certified that the S. N. Modern School located at A – 393, Shiv Mandir Road, New Ashok Nagar, Delhi – 110096, comprised of ground plus three upper floors owned/occupied by S. N. Modern School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/NDZ/2021/548 dated 28/07/2021. The School building was re-inspected by the officer concerned of this department on 10/07/2024 in presence of Mr. Deepak Kumar Aggarwal (Principal) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular letter No. 262 - 362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class **Group B “Educational Building”** with effect from 25/07/2024 for a period of **three years**, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 25/07/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

O/C DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi-110053.
2. The Principal, S. N. Modern School, A – 393, Shiv Mandir Road, New Ashok Nagar, Delhi – 110096.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/12
INSPECTION REPORT

1	Name & address of the building	S. N. Modern School located at A – 393, Shiv Mandir Road, Ashok Nagar, Delhi – 110096.		
2	Building is comprised of	Ground plus three upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/548 dated 28/07/2021		
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	10/07/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Deepak Aggarwal (Principal)		
10	Year of construction	1982		
11	Applicant's letter no.	Email dated 03/07/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Old Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A	Road width	6.0 mtrs.	9.0 mtrs. ✓ MR
	B	Gate width	N/A	N/A N/A
	C	Width of internal road	N/A	N/A N/A
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
		a	Upper floor	02 nos. 02 nos. ✓ MR
		b	Basement	N/A N/A N/A
	B	Width of staircases		
		a	Upper floor	1.50 mtrs 1.20 mtrs. & 1.0 mtrs. ✓ MR (old accepted)
		b	Basement	N/A N/A N/A
	C	Protection of exits		
		a	Fire check door	N/A N/A N/A
		b	Pressurization	N/A N/A N/A
	D	No. of continuous staircases to terrace		01 no. 02 nos. ✓ MR
	E	Width of corridor		1.50 mtrs. 1.80 mtrs ✓ MR
	F	Door size		1.0 mtr. 1.0 mtr ✓ MR
3	Compartmentation:			
	A	Fire check door		N/A N/A N/A
	B	Sealing of electrical shafts		N/A N/A N/A
	C	Fire rating of shaft door		N/A N/A N/A
	D	Water curtain		N/A N/A N/A
	E	Fire dampers		N/A N/A N/A
4	Smoke Management System:			
	A	Basement		N/A N/A N/A
	B	Upper floor		N/A N/A N/A

(10)


5	Fire Extinguisher:				
	A	Total numbers	08 nos.	08 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI marked	ISI marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no	MR
	B	Length of hose reel hose	30 mtrs.	30 mtr	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		Required	Provided	MR
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	100 mm	100 mm	MR
	B	Number of hydrants per floor	01 no.	01 no.	MR
	C	Hose box	01 no.	01 no.	MR
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	5000 liters	5000 liters	MR
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17 Standby Power Supply:				
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A	N/A

The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures required as per Circular No. 262-362 dated 17/01/2005, under the rules the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2021/548 dated 28/07/2021, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.


 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

DY.CFO (NDZ)

C.F.O.

Ring
19/07/24

Director
22/07/2021

Sir, RT letter is setup for sign. Please

Director
29/07/24


 24/7/2024