

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2024/WZ/ 499

Dated: 02/08/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s A-41, Mangol Puri Block-A, Industrial Area, Phase-II, Mangol Puri, Delhi-83, comprised of Ground + Mezzanine + First Floor only owned/occupied by Mr. Anil Wadhawan was issued FSC by this department vide letter No. F.6/DFS/MS/2021/WZ/372 dated 03.08.2021. The premises was re-inspected by the officer concerned of this department on 23.07.2024 in the presence of Sh. Harpreet (Head Currency Chest) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Business Occupancy" (Bank Chest) in Industrial Building with effect from 02/08/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/08/2024 at New Delhi by

  
(Atul Garg)  
DIRECTOR  
Ph; 011-23414000

Copy to :-

1. Sh. Anil Wadhawan (Owner), A-41, Mangol Puri Block-A, Industrial Area, Phase-II, Mangol Puri, Delhi-83.

**Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
2. The trained fire fighting staff should be available round the clock.
3. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
4. This certificate cannot be treated in any case for regularizations of unauthorized construction.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building	A-41, Mangol Puri Block-A, Industrial Area, Phase-II, Mangol Puri Delhi-83			
2. Type of Occupancy	Business Occupancy in Industrial Building (Bank Chest (Ground, Mezzanine & 1 <sup>st</sup> floor)			
3. Type of Case	Renewal (Ground, Mezzanine & 1 <sup>st</sup> floor)			
4. Details of Previous NOC	F.6/DFS/MS/2021/WZ/372 dated 03.08.2021.			
5. Fire Safety directives letter No	F.6/DFS/MS/BP/2012/711 dated 29.02.2012			
6. Date of inspection	23.07.2024			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Sh. Harpreet (Head Currency Chest)			
9. Year of Construction	1992			
10. Applicant's letter No.	Online e-mail dated 22.07.2024.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	1.25 & 1.5m	1.25 & 1.5m	MR
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	-NA-	-NA-	-NA-
	<b>e. Width of Corridor</b>	1.5m	1.5m	MR
	<b>f. Door Size</b>	1.0m	1.25m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	06nos.	06nos.	MR
	• Types	ABC/CO2/Wco2	ABC/CO2/Wco2	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	01nos.	Provided	MR

Dny

	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	a) Type of detectors	-NA-	Provided	-NA-
	b) Location of Main Panel	-NA-	Provided	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	Provided	-NA-
	e) Hooters' Location	-NA-	Provided	-NA-
<b>8.</b>	<b>MOEFA</b>	-NA-	-NA-	-NA-
<b>9.</b>	<b>Public Address System</b>	-NA-	-NA-	-NA-
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01nos.	Provided	MR
	• Hose Box	01nos.	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
<b>13.</b>	<b>Pumping Arrangements</b>			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	900lpm	900lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-

MR	• Fireman's Grounding Switch	Required	Provided	MR
MR	• Lift Signage	Required	Provided	MR
	Standby power supply	Required	Provided	MR
17.	<b>Refuge Area.</b>			
18.	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	<b>Fire Control Room</b>			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>			

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 265 dated 16.05.2024, the FSC issued vide letter no. F.6/DFS/MS/2021/WZ/372 dated 03.08.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

*[Signature]*  
25/7/24

Signature of the Inspecting Officer  
Name **Ajay Kumar Sharma**  
Designation **ADO(Rohini)**

DO(N/W)

*[Signature]*  
26/07/2024

By CFO (WZ)

*[Signature]*  
26/7

CFO

*[Signature]*  
29/7/2024

Director

*[Signature]*  
30/7/24

*[Signature]*

DCFO/.../6  
Dated...26.07.2024

FI letter is put up for kind perusal and signature please.

*[Signature]*  
25/7/24